

## Report for Periodic Monitoring of Emissions to Atmosphere

Part 1: **Executive Summary**

Permit Number: **N/A**

Operator: **Dunlop Oil and Marine**

Installation: **Grimsby**

Emission Point(s): **Rubber Mix 4 Inch Mill And Extraction**

Monitoring Date(s): **15<sup>th</sup> January 2016**



Contract Reference: FTBS 38567

Operator: Dunlop Oil and Marine

Address: Moody Lane, Pyewipe,  
Grimsby, North East Lincolnshire.  
DN312SY

Monitoring Organisation: RPS Consultants

Address: Noble House, Capital Drive, Linford  
Wood, Milton Keynes, MK14 6QP

Report Date: 16<sup>th</sup> February 2016


Report Approved By: Waheed Rasul

Position: Consultant

MCERTS Registration Number: MM 07 851

MCERTS Certification Level: Level 2

Technical Endorsements: TE1, TE2, TE3, TE4

Signature: 

RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

## **CONTENTS**

### **Part 1: Executive Summary**

**Section 1 – Monitoring Objectives** **Page 3**

**Section 2 – Monitoring Results** **Page 4**

**Section 3 – Operating Information** **Page 5**

**Section 4 – Monitoring Deviations** **Page 7**

### **Part 2: Supporting Information**

**Appendix 1 – Staff & Methodology Details**

**Appendix 2 – Rubber Mix 4 Inch Mill, Sampling, Analysis & Uncertainty Data**

**Appendix 3 – Extraction, Sampling, Analysis & Uncertainty Data**

**Appendix 4 – Laboratory Data**

## Monitoring Objectives

At the request of Chris Allen of Dunlop Oil and Marine Ltd. RPS Consultants conducted stack emission monitoring at the Moody Lane site in Grimsby in January 2016.

The monitoring programme at this installation was carried out to provide data on emissions to atmosphere for comparison with the limits specified in the air emission criteria for this site.

The following tables detail the parameters requested for monitoring at each emission point and the actual monitoring conducted.

**Table 1.1**

Parameters Requested to be Monitored	Emission Point
	Rubber Mix 4 Inch Mill
Total Particulate Matter	✓
<b>Specific Requirements</b>	Normal

Note : ✓ *Represents pollutants sampled*

**Table 1.2**

Parameters Requested to be Monitored	Emission Point
	Extraction
Total Particulate Matter	✓
<b>Specific Requirements</b>	Normal

Note : ✓ *Represents pollutants sampled*

## Monitoring Results

**Table 2.1 Monitoring results for the Rubber Mix 4 Inch Mill, Carried out on 15/01/2016**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	None Set	2.5	mg/m <sup>3</sup>	+/-0.25	273K, 101.3kPa, Wet	15/01/16	13:50 . 14:55	BS EN 13284-1:2002	None	Normal
	None Set	0.0326	kg/hr							

**Table 2.2 Monitoring results for the Extraction, Carried out on 15/01/2016**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	None Set	0.095	mg/m <sup>3</sup>	+/- 0.020	273K, 101.3kPa, Wet	15/01/16	11:00 . 14:45	None	None	Normal
	None Set	N/A	kg/hr							

## Operating Information

**Table 3.1 Operating conditions during the monitoring of the Rubber Mix 4 Inch Mill emission point, carried out on 15/01/2016**

Parameter	Result
Sample Date	15/01/06
Process Type	Normal
Process Duration	Continuous
If Batchq was monitoring carried out over the whole batch?	NA
Abatement/Operational?	NA

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m <sup>3</sup> )	Periodic Monitoring Results (mg/m <sup>3</sup> )
No CEMS Installed/Data Available		

**Table 3.2 Operating conditions during the monitoring of the Extraction emission point, carried out on 15/01/2016**

Parameter	Result
Sample Date	15/01/06
Process Type	Normal
Process Duration	Continuous
If Batch was monitoring carried out over the whole batch?	NA
Abatement/Operational?	NA

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m <sup>3</sup> )	Periodic Monitoring Results (mg/m <sup>3</sup> )
No CEMS Installed/Data Available		

## Monitoring Deviations

**Table 4.1 Monitoring Deviations for the Rubber Mix 4 Inch Mill Emission Point**

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

**Table 4.2 Monitoring Deviations for the Extraction Emission Point**

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None Accredited	Sample location does not allow for accredited testing as detailed in the proposal. No traverse profile could be carried out.

**Report for Periodic Monitoring of Emissions to Atmosphere**

Part 2: **Supporting Information**  
Permit Number: **N/A**  
Operator: **Dunlop Oil and Marine**  
Installation: **Grimsby**  
Emission Point(s): **Rubber Mix 4 Inch Mill and Extraction**  
Monitoring Date(s): **15<sup>th</sup> January 2016**



Contract Reference: FTBS 38567  
Operator: Dunlop Oil and Marine  
Address: Moody Lane, Pyewipe,  
Grimsby, North East Lincolnshire.  
DN312SY  
Monitoring Organisation: RPS Consultants  
Address: Noble House, Capital Drive, Linford  
Wood, Milton Keynes, MK14 6QP  
Report Date: 16<sup>th</sup> February 2016  
Report Approved By: Waheed Rasul  
Position: Consultant  
MCERTS Registration Number: MM 07 851  
MCERTS Certification Level: Level 2  
Technical Endorsements: TE1, TE2, TE3, TE4  
Signature: *Waheed Rasul*

RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.



## **CONTENTS**

### **Part 1: Executive Summary**

<b>Section 1 – Monitoring Objectives</b>	<b>Page 3</b>
<b>Section 2 – Monitoring Results</b>	<b>Page 4</b>
<b>Section 3 – Operating Information</b>	<b>Page 5</b>
<b>Section 4 – Monitoring Deviations</b>	<b>Page 7</b>

### **Part 2: Supporting Information**

**Appendix 1 – Staff & Methodology Details**

**Appendix 2 – Rubber Mix 4 Inch Mill, Sampling, Analysis & Uncertainty Data**

**Appendix 3 – Extraction, Sampling, Analysis & Uncertainty Data**

**Appendix 4 – Laboratory Data**

## **APPENDIX 1: General Information**

## Monitoring Organisation Staff Details

**Table 5.1 Sampling Personnel**

Sampling Personnel	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Chris Davies	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 03 252
James Beechey	Technician	Level 1	TE1, TE2	MM 11 1144

**Table 5.2 Report Author**

Report Author	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Chris Davies	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 03 252

**Table 5.3 Report Reviewer**

Report Reviewer	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Waheed Rasul	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 07 851

## Monitoring Organisation Method Details

**Table 6.1 Monitoring Methods**

Emission Parameter	Standard Method	Monitoring Procedure No.	Monitoring Accreditation	Analysis	Analysis Procedure No.	Analytical Laboratory	Analysis Accreditation
Practical Considerations Prior to Monitoring	N/A	RPSCE/1/1	UKAS	N/A	N/A	N/A	N/A
Gas Flows	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Gas Temperatures	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Low Concentration Total Particulate Matter	BS-EN 13284-1:2001	RPSCE/1/7c	MCERTS	Gravimetric	D9	RPS Laboratories	UKAS

**Table 7.1 – Checklist Used**

Equipment Checklist Used	File Location Address
FTBS38567 Checklist	FTBS38567 Electronic & Work File

**APPENDIX 2:  
Rubber Mix 4 Inch Mill Sampling, Analysis & Uncertainty Data**

## Stack Diagram



Company Name: Dunlop Oil and Marine  
Site Name: Grimsby  
Sampling Point Ref: 4 Inch Mill  
Project Reference: FTBS38567

Date: 15/01/16  
Run: TPM

Δp Measurement units (Pa or mmH2O)	mmH2O
------------------------------------	-------

Barometric	753	mmHg	Leak Test		
Static			Instrument range		mmH2O
Port A	2	mmH2O	Δp for leak test		mmH2O
Port B	2	mmH2O	Positive leakage rate		per 15secs
Mean	2	mmH2O	Negative leakage rate		per 15secs
			Pass/Fail	Fail	

Stagnation Test		
Static measurement		
Positive side	0.1	mmH2O
Negative side	0.1	mmH2O
Difference (Pa)	0	
Pass/Fail	Pass	

Stack Dimensions		
Rectangular A		m
Rectangular B		m
Circular diam A	0.6	m
Circular diam B	0.6	m
Circular Mean	0.6	m
Area	0.2827431	m <sup>2</sup>

Traverse Point	Distance m	Port A					Swirl Degrees	Temp °C	Port B				
		Δ p. mmH2O			Average	Δ p. mmH2O			Average	Swirl	Temp °C		
		Reading 1	Reading 2	Reading 3		Reading 1						Reading 2	Reading 3
1		16	16	16	16.0		12	15.5	16	16	15.8		12
2		17	17	17	17.0		12	16	16.5	16	16.2		12
3		17	17	16.5	16.8		12	16.5	17	16.5	16.7		12
4		16.5	16	16	16.2		12	17	17	16.5	16.8		12
5		17	16.5	16	16.5		12	17	17	16.5	16.8		12
6		16.5	17	16.5	16.7		12	17	17	17	17.0		12
7		16.5	16.5	16	16.3		12	16.5	16.5	17	16.7		12
8		16.5	16	16	16.2		12	16.5	17	16.5	16.7		12
9		16	16	15.5	15.8		12	16.5	17	16.5	16.7		12
10		16	16	16	16.0		12	16	16.5	16	16.2		12

Gas Data	
Oxygen %	20.9
CO <sub>2</sub> %	0.10
CO %	0.1

Oxygen Correction	
Required Correction Value	0
Actual Oxygen Factor	1.00
<i>Enter '0' if correction is not required</i>	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	Yes
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	Yes
Handrails with removable chains / self closing gates across the top of the ladder?	Yes
Handrails (approx 0.5 and 1.0 m high) and vertical baseboards (approx 0.25m high)?	Yes
Scaffold Built to 'Heavy Duty' Scafftag rating or 2.5kN/m <sup>2</sup> load rating minimum	NA
Handrails not restricting access to ports?	Yes
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	Yes
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Dunlop Oil and Marine    In-stack Filter? **Y**    Bar. Press.mm Hg **753**    K Factor **2.57**    Ambient Temp. **12**    Leak Rate (fin / %) **0.02**  
 Site Name: Grimsby    Outstack Filter? **N**    Cp **0.823**    Dn used **5.8**    Start Time **13:50**    Leak Rate (start / %) **0.02**  
 Project Reference: FTBS38567    Date: **15/01/16**    Run: **TPM**    Operators **CD - JB**    Bws% **1**    Nozzle No. **FYS367 -6**    Stop Time **14:55**    Box/Probe setting **160 +/- 5 °C**  
 Sampling Point Ref: 4 Inch Mill    Meter Correction Yd **0.978**

Sample Filter Weights			
	Sample ID	Laboratory	Increase, mg
Filter	128116	RPS	2.01
Probe Washings	20009734	RPS	1.04

Sample Filter Blank Weighings			
	Sample ID	Laboratory	Increase, mg
Filter	125691	RPS	<b>0.04</b>
Probe Wash	20009733	RPS	<b>0.5</b>

Note: Results in Bold are reported at the L.O.D.

Impinger Weights			
Weights	Initial	Final	Increase, g
Impinger 1	798.8	793.8	-5.0
Impinger 2	592.8	592.4	-0.4
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	816.8	826.5	9.7
		Total	4.3

Sample Point	Clock Time min	Pitot Δ p, mm H <sub>2</sub> O	Stack Temp, °C	Orifice Δ H, mm H <sub>2</sub> O		Gas Meter Reading m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Root Δ p,
				Desired	Actual								
	0	16	12	41.12	41.12	6966	10	-	-	-	-1	8	4.000
	5	16.5	12	42.405	42.405		10	-	-	-	-1	8	4.062
	10	17	12	43.69	43.69		11	-	-	-	-1	9	4.123
	15	17	12	43.69	43.69		11	-	-	-	-1	9	4.123
	20	16.5	12	42.405	42.405		12	-	-	-	-1	9	4.062
	25	16.5	12	42.405	42.405		12	-	-	-	-1	10	4.062
Endpoint	30												
	0	16	12	41.12	41.12	8265	12	-	-	-	-1	10	4.000
	5	16.5	12	42.405	42.405		13	-	-	-	-1	10	4.062
	10	17	12	43.69	43.69		13	-	-	-	-1	10	4.123
	15	17	12	43.69	43.69		14	-	-	-	-1	11	4.123
	20	17	12	43.69	43.69		14	-	-	-	-1	11	4.123
	25	16.5	12	42.405	42.405		15	-	-	-	-1	12	4.062
Endpoint	30												
	<b>60.00</b>	<b>16.625</b>	<b>12.0</b>	<b>42.7</b>	<b>42.7</b>	<b>1.299</b>	<b>12.3</b>				<b>-1.0</b>	<b>9.8</b>	<b>4.1</b>



Company Name: Dunlop Oil and Marine  
Site Name: Grimsby  
Project Reference: FTBS38567  
Sampling Point Ref: 4 Inch Mill

Date: 15/01/16  
Run: TPM

Meter Volume Sampled, (Actual m <sup>3</sup> )	1.299
Sample Run Start Time	13:50
Sample Run End Time	14:55
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	753.00
Stack Pressure, mm Hg	753.15
Average Stack Temp, °C	12.0
Meter Volume (Standardised m <sup>3</sup> ), Dry	1.209
Meter Volume (Standardised m <sup>3</sup> ) Wet	1.214
Stack Moisture Content, %	0.4
Oxygen Reference Value	0.0
Oxygen Correction Factor	1.0
Stack Gas Analysis            %CO <sub>2</sub>	0.10
%O <sub>2</sub>	20.90
Average Stack Velocity, m/sec	13.446
Stack Area, m <sup>2</sup>	0.28
Stack Flow Rate, (Actual m <sup>3</sup> /s)	3.802
Stack Flow Rate (Standardised m <sup>3</sup> /s) wet	3.607
Stack Flow Rate, (Standardised m <sup>3</sup> /s), dry	3.591
Nozzle Diameter, mm	5.80
% Isokinetic Variation	99.9
Mass of Particulate Collected on Filter, mg	2.0
Mass of Particulate collected in Probe, mg	1.0
Total Mass of Particulate, mg	3.1
Percentage of Total Particulate Collected on Filter	65.9
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>2.512</b>
Particulate Mass rate, kg/hour	0.033
Emission Limit value	<b>None Set</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.44
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	N/A

**Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1**

Determined Concentration	2.512	mg/m <sup>3</sup> (at Reference Cond)
--------------------------	-------	---------------------------------------

**Measured Values**

Sampled Volume	1.299	m <sup>3</sup>
Sampled gas Temperature	285.25	k
Sampled gas Pressure	100.42	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	3.05	mg

Leak	0.02	%
Uncollected Mass	0	mg

**Standard Uncertainties for Measured Values**

Sampled Volume	0.001	m <sup>3</sup>
Sampled gas Temperature	2	k
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction				Uncertainty Calculation for Oxygen Correction			
Volume Correction Factor	0.949			Oxygen Correction Factor	1.0000		
	<b>Sensitivity Coefficient</b>		<b>Uncertainty, Uv</b>		<b>Sensitivity Coefficient</b>		<b>Uncertainty, Uo</b>
Sampled gas Temperature	0.0033		0.0067	Oxygen Measurement	N/A		N/A
Sampled gas Pressure	0.0094		0.0094				
Sampled gas Humidity	0.0095		0.0095				
		<b>Sqrt (Uv)^2</b>	0.0150				
		<b>Total Uv</b>	<b>0.019</b>			<b>Total Uo</b>	<b>N/A</b>

Uncertainty Contributions (Itemised)						
	Value		Sensitivity coefficient	Uncertainty Contribution		
				Concentration	%	
Volume Correction	1.209	m <sup>3</sup>	2.08	0.04 mg.m <sup>-3</sup>	1.61 %	
Mass (weighing)	3.05	mg	0.82	0.12 mg.m <sup>-3</sup>	4.64 %	
Oxygen Correction	N/A		0.00	0.00 mg.m <sup>-3</sup>	0.00 %	
System Leak	0.00	mg.m <sup>-3</sup>	1.00	0.00 mg.m <sup>-3</sup>	0.01 %	
Uncollected Mass	0.00	mg	0.82	0.00 mg.m <sup>-3</sup>	0.00 %	
			<b>Total Uncertainty</b>	<b>0.12 mg.m<sup>-3</sup></b>		

Uncertainty Result	
(Uncertainty has been expanded with a coveragefactor of 2 (K=2))	
<b>Expanded Uncertainty =</b>	<b>0.2467 mg.m<sup>-3</sup></b>
<b>=&gt;</b>	<b>9.82 % of Result</b>
<b>=&gt;</b>	<b>N/A % of ELV</b>

**APPENDIX 3:  
Extraction Sampling, Analysis & Uncertainty Data**

Stack Ref: Extraction Company Name: Dunlop Oil and Marine Site Ref: Grimsby			Personnel: JB CD		
			Date of Sampling: 15/01/2016		
			<b>Sampling Comments</b>		
Ref Moisture	-	wet			
Ref Temp	K	273			
Ref Pressure	kPa	101.325			
Ref Oxygen	%	20.9			
	Start	End			
<b>Sample Times</b>	<b>11:00</b>	<b>14:45</b>			
<b>Barometric</b>	<b>kPa</b>	<b>101.3</b>	Measured Volume	m <sup>3</sup>	0.450
Static Pressure	Pa	0.0	Volume at STP	m <sup>3</sup>	0.419
Duct Diameter	m		<b>Area of Duct</b>	<b>m<sup>2</sup></b>	<b>0.000</b>
Average Stack Temperature	°C	20	Duct Pressure	kPa	101.300
Meter Correction Yd	-	1	Mean Sum SQRT Delta P	Pa	0.00
Meter Temp Average	°C	20	<b>Velocity</b>	<b>m/s</b>	<b>#DIV/0!</b>
Meter Volume (Start)	m <sup>3</sup>	0	<b>Vol Flow (as Measured)</b>	<b>m<sup>3</sup>/s</b>	<b>#DIV/0!</b>
Meter Volume (End)	m <sup>3</sup>	0.45	<b>Vol Flow (corrected)</b>	<b>m<sup>3</sup>/s</b>	<b>#DIV/0!</b>
Pitot Coefficient	-	1.00	Mass Emission	kg/hr	#VALUE!
Measured Oxygen	%	20.9	Moisture Content	%	0.00000
<b>Laboratory Data</b>			<b>Mass Concentration (at reference conditions)</b>		
Filter No:- 118395	mg	0.04		mg/m <sup>3</sup>	0.095
Filter No:-106812	mg	0.04		mg/m <sup>3</sup>	0.095
Mean	mg	0.04	Mean	mg/m <sup>3</sup>	0.095

### Uncertainty Calculation Sheet -

Studied Concentration (mg/m <sup>3</sup> )	0.09542444
--	------------

Selected Performance Characteristic	Value	Units	Variability due to sampling	Manual Method
Laboratory Analysis	20	%		
O2 Correction	0.2	%		
Gas Meter Volume, sampling rate	2	%		
Atmospheric Pressure Dependence	1	%/kPa	0.2	kPa
Temperature Dependence	0.4	% K	5	C
Desorption Efficiency	10	%		
Sample Handling (Handling)	1	%		
Losses in Sample Train (Leakage)	2	%		

Performance Characteristic	Uncertainty Quantity	At Calibration Conditions		At Sampling Conditions	
		U	U <sup>2</sup>	U	U <sup>2</sup>
Laboratory Analysis	U <sub>analysis</sub>	0.019085	0.000364	0.019085	0.000364
O2 Correction	U <sub>correction</sub>	0.001908	0.000004	0.001908	0.000004
Gas Meter Volume, sampling rate	U <sub>volume</sub>	0.001102	0.000001	0.001102	0.000001
Atmospheric Pressure Dependence	U <sub>pres</sub>	0.000551	0.000000	0.000110	0.000000
Temperature Dependence	U <sub>temp</sub>	0.000220	0.000000	0.001102	0.000001
Desorption Efficiency	U <sub>des</sub>	0.005509	0.000030	0.005509	0.000030
Sample Handling (transport etc)	U <sub>handling</sub>	0.000551	0.000000	0.000551	0.000000
Losses in Sample Train (Leakage)	U <sub>losses, leaks</sub>	0.001102	0.000001	0.001102	0.000001

Measurement Uncertainty at	0.09542444	mg/m <sup>3</sup>		
U <sub>tot</sub>	0.0201	mg/m <sup>3</sup>		
U <sub>tot</sub> <sup>C</sup>	21.0	%	U <sub>limit</sub>	

## **APPENDIX 4: Laboratory Data**



**Test Certificate**

Date 08/02/2016

<b>Client</b>	RPS Milton Keynes HSED Noble House Capital Drive Linford Wood Milton Keynes MK14 6QP	<b>Order No.</b>	FTBS 38561
		<b>Certificate No.</b>	WK16-0515
		<b>Issue No.</b>	1

<b>Contact</b>	Chris Davies	<b>Date Received</b>	02/02/2016
<b>Description</b>	2 Filters & Washes for TPM	<b>Technique</b>	Gravimetric

Sample No.	867468	127293	Method
Total particulate matter	<0.04 mg		D8(U)
Sample No.	867469	20009476	Method
Total particulate matter	<0.5 mg		D8(U)
Sample No.	867470	128267	Method
Total particulate matter	<0.04 mg		D8(U)
Sample No.	867471	20009477	Method
Total particulate matter	3.56 mg		D8(U)



Test Certificate

Date 08/02/2016

Client	RPS Milton Keynes HSED	Certificate No.	WK16-0515
		Issue No.	1

Tested By Simon Doodson Date 08/02/2016

Approved By  Date 08/02/2016  
Joanne Dewhurst  
Operational Manager

For and on authority of RPS Laboratories Ltd.

Method Symbols (U) Analysis is UKAS Accredited  
(N) Analysis is not UKAS Accredited

Concentration values (mg/m<sup>3</sup> and ppm) are calculated on the basis of information provided by the customer.  
Results stated as ml are referring to the sample volume.

RPS Laboratories terms and conditions apply - a copy is available on request.

Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory.





Test Certificate

Date 03/02/2016

<b>Client</b>	RPS Milton Keynes HSED Noble House Capital Drive Linford Wood Milton Keynes MK14 6QP	<b>Order No.</b>	FTOM 38601
		<b>Certificate No.</b>	WK16-0298
		<b>Issue No.</b>	1
<b>Contact</b>	James Beechey	<b>Date Received</b>	21/01/2016
<b>Description</b>	5 filters for TID	<b>Technique</b>	Gravimetric

Sample No.	866407	119944	Method
<b>Total inhalable dust</b>	0.06 mg	0.11 mg/m <sup>3</sup>	D1(U)
Sample No.	866408	120524	Method
<b>Total inhalable dust</b>	0.16 mg	0.30 mg/m <sup>3</sup>	D1(U)
Sample No.	866409	120523	Method
<b>Total inhalable dust</b>	0.12 mg	0.22 mg/m <sup>3</sup>	D1(U)
Sample No.	866412	118395	Method
<b>Total inhalable dust</b>	<0.04 mg	<0.09 mg/m <sup>3</sup>	D1(U)
Sample No.	866413	106812	Method
<b>Total inhalable dust</b>	<0.04 mg	<0.09 mg/m <sup>3</sup>	D1(U)



Test Certificate

Date 03/02/2016

<b>Client</b>	RPS Milton Keynes HSED	<b>Certificate No.</b>	WK16-0298
		<b>Issue No.</b>	1

**Tested By** Simon Doodson **Date** 03/02/2016

**Approved By**  **Date** 03/02/2016

Joanne Dewhurst  
Operational Manager

For and on authority of RPS Laboratories Ltd.

Method Symbols (U) Analysis is UKAS Accredited  
(N) Analysis is not UKAS Accredited

Concentration values (mg/m<sup>3</sup> and ppm) are calculated on the basis of information provided by the customer.  
Results stated as ml are referring to the sample volume.

RPS Laboratories terms and conditions apply - a copy is available on request.  
Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory.