

# STACK EMISSIONS MONITORING REPORT



Unit 5 Crown Industrial Estate  
Kenwood Road  
Stockport  
SK5 6PH  
Tel: 0161 443 0980  
Fax: 0161 443 0989

## Your contact at ESG

Mark Woodruff  
Business Manager - North  
Tel: 0161 443 0982  
Email: mark.woodruff@esg.co.uk

## Operator & Address:

Energy Pyrolysis  
West Factory Bale Store  
Great Coates Industrial Estate  
Moody Lane  
Grimsby  
DN31 2SS

## Permit:

EPR Permit: EP20140001

## Release Point:

Main Process Exhaust

## Sampling Date(s):

5th - 7th December 2017

<b>ESG Job Number:</b>	LNO 13348 / Q4
<b>Report Date:</b>	16th January 2018
<b>Version:</b>	1
<b>Report By:</b>	Dominic Houghton
<b>MCERTS Number:</b>	MM 04 529
<b>MCERTS Level:</b>	MCERTS Level 2 - Team Leader
<b>Technical Endorsements:</b>	1, 2, 3 & 4
<b>Report Approved By:</b>	Keith Bird
<b>MCERTS Number:</b>	MM 07 825
<b>Business Title:</b>	MCERTS Level 2 - Team Leader
<b>Technical Endorsements:</b>	1, 2, 3 & 4
<b>Signature:</b>	



1015



## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

#### Monitoring Times

#### Process Details

#### Monitoring Methods

#### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

#### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

#### Sampling and Analytical Method Deviations

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

Energy Pyrolysis operates a rubber recycling process at Grimsby which is subject to EPR Permit EP20140001, under the Environmental Permitting Regulations 2010.

ESG were commissioned by Mabbett & Associates Ltd to carry out stack emissions monitoring to determine the release of prescribed pollutants from the following Plant under normal operating conditions.

The results of these tests shall be used to demonstrate compliance with a set of emission limit values for prescribed pollutants as specified in the Plant's EPR Permit, EP20140001.

#### **Plant**

Main Process Exhaust

#### **Operator**

Energy Pyrolysis  
West Factory Bale Store  
Great Coates Industrial Estate  
Moody Lane  
Grimsby  
DN31 2SS

EPR Permit: EP20140001

#### **Stack Emissions Monitoring Test House**

ESG - Stockport Laboratory  
Unit 5 Crown Industrial Estate  
Kenwood Road  
Stockport  
SK5 6PH  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.  
MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.  
This test report shall not be reproduced, except in full, without written approval of ESG.

## EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
Parameter	Units	Result	Calculated Uncertainty +/-	Limit	MCERTS accredited result
<b>Dioxins &amp; Furans - UPPER Limits</b>					
Dioxins & Furans (NATO I-TEQ)	ng/m <sup>3</sup>	0.0014	0.0019	0.1	✓
Dioxins & Furans (NATO I-TEQ) Emission Rate	µg/hr	0.0014	0.0019	-	
Dioxins & Furans (WHO TEQ Humans / Mammals)	ng/m <sup>3</sup>	0.0014	0.0020	-	✓
Dioxins & Furans (WHO TEQ H / M) Emission Rate	µg/hr	0.0014	0.0020	-	
Dioxins & Furans (WHO TEQ Fish)	ng/m <sup>3</sup>	0.0015	0.0022	-	✓
Dioxins & Furans (WHO TEQ Fish) Emission Rate	µg/hr	0.0015	0.0022	-	
Dioxins & Furans (WHO TEQ Birds)	ng/m <sup>3</sup>	0.0022	0.0031	-	✓
Dioxins & Furans (WHO TEQ Birds) Emission Rate	µg/hr	0.0022	0.0031	-	
<b>Dioxins &amp; Furans - LOWER Limits</b>					
Dioxins & Furans (NATO I-TEQ)	ng/m <sup>3</sup>	0.0008	0.0012	-	✓
Dioxins & Furans (NATO I-TEQ) Emission Rate	µg/hr	0.0008	0.0012	-	
Dioxins & Furans (WHO TEQ Humans / Mammals)	ng/m <sup>3</sup>	0.0007	0.0010	-	✓
Dioxins & Furans (WHO TEQ H / M) Emission Rate	µg/hr	0.0007	0.0010	-	
Dioxins & Furans (WHO TEQ Fish)	ng/m <sup>3</sup>	0.0007	0.0010	-	✓
Dioxins & Furans (WHO TEQ Fish) Emission Rate	µg/hr	0.0007	0.0010	-	
Dioxins & Furans (WHO TEQ Birds)	ng/m <sup>3</sup>	0.0016	0.0022	-	✓
Dioxins & Furans (WHO TEQ Birds) Emission Rate	µg/hr	0.0016	0.0022	-	
Cadmium & Thallium	mg/m <sup>3</sup>	0.00065	0.00096	0.05	✓
Cadmium & Thallium Emission Rate	g/hr	0.00068	0.00100	-	
Heavy Metals	mg/m <sup>3</sup>	0.093	0.0102	0.5	✓
Heavy Metals Emission Rate	g/hr	0.097	0.0107	-	
Mercury	mg/m <sup>3</sup>	0.00027	0.00046	0.05	✓
Mercury Emission Rate	g/hr	0.00028	0.00048	-	
Hydrogen Chloride	mg/m <sup>3</sup>	0.30	0.035	20	✓
Hydrogen Chloride Emission Rate	g/hr	0.29	0.034	-	
Hydrogen Fluoride	mg/m <sup>3</sup>	<b>0.03</b>	0.004	2	✓
Hydrogen Fluoride Emission Rate	g/hr	<b>0.03</b>	0.004	-	
Oxides of Nitrogen (as NO <sub>2</sub> )	mg/m <sup>3</sup>	5.7	12	400	✓
Oxides of Nitrogen (as NO <sub>2</sub> ) Emission Rate	g/hr	5.6	12	-	
Sulphur Dioxide	mg/m <sup>3</sup>	5.7	14	100	✓
Sulphur Dioxide Emission Rate	g/hr	5.6	14	-	
Carbon Monoxide	mg/m <sup>3</sup>	3.5	3.4	150	✓
Carbon Monoxide Emission Rate	g/hr	3.4	3.3	-	
Nitrous Oxide	mg/m <sup>3</sup>	0.35	1.3	-	✓
Nitrous Oxide Emission Rate	g/hr	0.34	1.3	-	
Moisture	%	2.5	1.33	-	✓
Stack Gas Temperature	°C	50	-	-	
Stack Gas Velocity	m/s	6.5	0.17	-	
Gas Volumetric Flow Rate (Actual)	m <sup>3</sup> /hr	1150	60	-	✓
Gas Volumetric Flow Rate (STP, Wet)	m <sup>3</sup> /hr	979	51	-	
Gas Volumetric Flow Rate (STP, Dry)	m <sup>3</sup> /hr	955	50	-	
Gas Volumetric Flow Rate at Reference Conditions	m <sup>3</sup> /hr	979	51	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from the preliminary survey. Mass emissions for non isokinetic tests are calculated using these values. For all isokinetic testing the mass emission is calculated using test specific flow data and not the above values.

Reference conditions are 273K, 101.3kPa without correction for water vapour

## EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
Dioxins & Furans Run 1	07 December	09:25 - 15:25	360 minutes
Cadmium & Thallium Run 1	05 December	12:40 - 14:40	120 minutes
Heavy Metals Run 1	05 December	12:40 - 14:40	120 minutes
Mercury Run 1	05 December	12:40 - 14:40	120 minutes
Hydrogen Chloride Run 1	05 December	11:05 - 12:05	60 minutes
Hydrogen Fluoride Run 1	05 December	15:15 - 16:15	60 minutes
Combustion Gases	06 December	11:30 - 15:30	240 minutes
Preliminary Stack Traverse	05 December	10:40	-

## EXECUTIVE SUMMARY

### PROCESS DETAILS

Parameter	Process Details
Description of process	Rubber recycling
Continuous or batch	Batch
Product Details	Diesel and Carbon
Part of batch to be monitored (if applicable)	When operating at temperature
Normal load, throughput or continuous rating	Normal Load
Fuel used during monitoring	LPG and recycled process gas
Abatement	None
Plume Appearance	Plume Visible

## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by ESG is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

MONITORING METHODS						
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	Calculated MU +/- %
PCDD/PCDF	SRM - BS EN 1948-1	AE 109	1015	Yes	0.001 ng/m <sup>3</sup>	141%
Cd & Tl	SRM - BS EN 14385	AE 108	1015	Yes	0.00047 mg/m <sup>3</sup>	147%
Heavy Metals	SRM - BS EN 14385	AE 108	1015	Yes	0.002 mg/m <sup>3</sup>	11%
Mercury	SRM - BS EN 13211 / MID 14385	AE 107/AE 108	1015	Yes	0.0002 mg/m <sup>3</sup>	173%
Hydrogen Chloride	SRM - BS EN 1911	AE 111	1015	Yes	0.0007 mg/m <sup>3</sup>	11.7%
Hydrogen Fluoride	SRM - BS ISO 15713	AE 113	1015	Yes	0.01 mg/m <sup>3</sup>	14%
NO <sub>x</sub>	AM - M22/FTIR	AE 063	1015	Yes	3.5 mg/m <sup>3</sup>	210.4%
SO <sub>2</sub>	AM - M22/FTIR	AE 063	1015	Yes	0.4 mg/m <sup>3</sup>	245.1%
CO	AM - M22/FTIR	AE 063	1015	Yes	0.1 mg/m <sup>3</sup>	96.2%
N <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	0.3 mg/m <sup>3</sup>	372.9%
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	0.1 %	53.93%
Velocity	SRM - BS EN ISO 16911-1	AE 154	1015	Yes	5 Pa	2.6%
Volumetric Flow Rate	SRM - BS EN ISO 16911-1	AE 154	1015	Yes	-	5.2%

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Lab Analysis	Analysis Lab	Sample Archive Location	Archive Period
PCDD/PCDF	Gas Chromatography - High Resolution Mass Spectrometry	MSOP1	1549	Yes	SAL	SAL	8 Weeks
Cd & Tl	Inductively coupled Plasma - Mass Spectrometry	ASC/SOP/117	ESG - Bretby	Yes	ESG - Bretby	ESG - Bretby	8 Weeks
Heavy Metals	Inductively coupled Plasma - Mass Spectrometry	ASC/SOP/117	ESG - Bretby	Yes	ESG - Bretby	ESG - Bretby	8 Weeks
Mercury	Inductively coupled Plasma - Mass Spectrometry	ASC/SOP/117	ESG - Bretby	Yes	ESG - Bretby	ESG - Bretby	8 Weeks
Hydrogen Chloride	Ion Chromatography	ASC/SOP/110	1015	Yes	ESG Bretby	ESG Bretby	8 Weeks
Hydrogen Fluoride	Ion Chromatography	ASC/SOP/110	1015	Yes	ESG Bretby	ESG Bretby	8 Weeks

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Data Archive Location	Archive Period
NO <sub>x</sub>	Fourier Transform - Infra Red	AE 102	1015	Yes	ESG Stockport	ESG Stockport	5 years
SO <sub>2</sub>	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Stockport	ESG Stockport	5 years
CO	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Stockport	ESG Stockport	5 years
N <sub>2</sub> O	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Stockport	ESG Stockport	5 years
H <sub>2</sub> O	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Stockport	ESG Stockport	5 years



## EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	31	Pa	>= 5 Pa	Yes	BS EN 15259
Lowest Gas Velocity	6.5	m/s	-	-	-
Highest Gas Velocity	6.5	m/s	-	-	-
Ratio of Gas Velocities	1.0	: 1	< 3 : 1	Yes	BS EN 15259
Mean Velocity	6.5	m/s	-	-	-
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes	BS EN 15259
No local negative flow	Yes	-	-	Yes	BS EN 15259

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	0.25	m
Width	-	m
Area	0.05	m <sup>2</sup>
Port Depth	60	mm

SAMPLING LINES & POINTS		
	Isokinetic	Non-Iso & Gases
Sample port size	4 inch BSP	4 inch BSP
Number of lines used	1	1
Number of points / line	1	1
Duct orientation	Vertical	Vertical
Filtration	Out Stack	Out Stack

SAMPLING PLATFORM	
<b>General Platform Information</b>	
Permanent / Temporary Platform / Ground level / Floor Level / Roof	Floor Level
Inside / Outside	Outside
<b>M1 Platform requirements</b>	
Is there a sufficient working area so work can be performed in a compliant manner	Yes
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	No
Platform has vertical base boards (approximately 0.25 m high)	No
Platform has removable chains / self closing gates at the top of ladders	No
Handrail / obstructions do not hamper insertion of sampling equipment	Yes
Depth of Platform = >Stack depth / diameter + wall and port thickness + 1.5m	No

### Sampling Platform Improvement Recommendations (if applicable)

A sampling platform with sufficient depth should be constructed to meet the requirements of EA Guidance Note M1.

## EXECUTIVE SUMMARY

### Sampling & Analytical Method Deviations

In this instance there were no deviations from the sampling and analytical methods employed.

APPENDICES

**CONTENTS**

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

MONITORING SCHEDULE					
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Number of Samples
PCDD/PCDF	SRM - BS EN 1948-1	AE 109	1015	Yes	1
Cd & Tl	SRM - BS EN 14385	AE 108	1015	Yes	1
Heavy Metals	SRM - BS EN 14385	AE 108	1015	Yes	1
Mercury	SRM - BS EN 13211 / MID 14385	AE 107/AE 108	1015	Yes	1
Hydrogen Chloride	SRM - BS EN 1911	AE 111	1015	Yes	1
Hydrogen Fluoride	SRM - BS ISO 15713	AE 113	1015	Yes	1
NOx	AM - M22/FTIR	AE 063	1015	Yes	1
SO <sub>2</sub>	AM - M22/FTIR	AE 063	1015	Yes	1
CO	AM - M22/FTIR	AE 063	1015	Yes	1
Nitrous Oxide	AM - M22/FTIR	AE 063	1015	Yes	1
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	1
Velocity	SRM - BS EN ISO 16911-1	AE 154	1015	Yes	1

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATEABLE EQUIPMENT CHECKLIST					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	LNO 13-08	Horiba PG-250 Analyser	-	Laboratory Balance	LNO 00-12/00-13
Box Thermocouples	LNO 03-08	FT-IR Protea	LNO Protea	Tape Measure	LNO 24-DJH
Meter In Thermocouple	LNO 03-08	FT-IR Oven Box	-	Stopwatch	LNO 17-DJH
Meter Out Thermocouple	LNO 03-08	Bernath 3006 FID	-	Protractor	-
Control Box Timer	LNO 17-01	Signal 3030 FID	-	Barometer	LNO 08-DJH
Oven Box	LNO 13-12	Servomex	-	Digital Micromanometer	LNO 01-DJH
Probe	LNO 11-25	JCT Heated Head Filter	-	Digital Temperature Meter	LNO 03-DJH
Probe Thermocouple	LNO 10-25	Thermo FID	LNO 21-10	Stack Thermocouple	-
Probe	-	Stackmaster	-	Mass Flow Controller	LNO 29-13
Probe Thermocouple	-	FTIR Heater Box for Heated Line	-	MFC Display module	LNO 29-11
S-Pitot	LNO 06-DJH	Anemometer	-	1m Heated Line (1)	-
L-Pitot	LNO 10-104 / 06-104	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	LNO 14-DJH	Chiller (JCT/MAK 10)	-	1m Heated Line (3)	-
Last Impinger Arm	-	Heated Line Controller (1)	LNO 03-91	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	-	Heated Line Controller (2)	-	10m Heated Line (1)	-
Callipers	LNO 31-DJH	Site temperature Logger	LNO 12-JO	10m Heated Line (2)	-
Small DGM	-		-	15m Heated Line (1)	LNO 18-65
Heater Controller	-		-	20m Heated Line (1)	-
Inclinometer (Swirl Device)	LNO 23-DJH		-	20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION / CHECK GASES					
Gas (traceable to ISO 17025)	Cylinder I.D Number	Supplier	ppm	%	Analytical Tolerance +/- %
Methane	120876	BOC	105	-	2.0
Carbon Monoxide	221325	BOC	78	-	2.0
Nitric Oxide	HPC882	BOC	79.8	-	2.0
Oxides of Nitrogen	HPC882	BOC	79.8	-	2.0
Sulphur Dioxide	245944	BOC	404	-	2.0
Nitrous Oxide	249413	BOC	41.8	-	2.0

**STACK EMISSIONS MONITORING TEAM**

MONITORING TEAM								
Personnel	MCERTS Number	MCERTS		TE / H&S Qualifications and Expiry Date				
		Level	Expiry	TE1	TE2	TE3	TE4	H&S
Dominic Houghton	MM 04 529	MCERTS Level 2	Mar-18	Dec-21	Dec-21	Mar-18	Dec-21	Sep-19
Mike Howell	MM 13 1226	MCERTS Level 1	Jul-19	Jul-20	Mar-21	-	-	Jun-20

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS SUMMARY - UPPER LIMIT**

NATO I-TEQ					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	09:25 - 15:25 07 December 2017	0.0014	0.0013	0.1	0.001
Field Blanks Run 1	-	0.00107	-	-	-

WHO TEQ (Humans / Mammals)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	09:25 - 15:25 07 December 2017	0.0014	0.0012	-	0.001
Field Blanks Run 1	-	0.0011	-	-	-

WHO TEQ (Fish)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	09:25 - 15:25 07 December 2017	0.0015	0.0014	-	0.002
Field Blanks Run 1	-	0.0012	-	-	-

WHO TEQ (Birds)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	09:25 - 15:25 07 December 2017	0.0022	0.0014	-	0.002
Field Blanks Run 1	-	0.0017	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS SUMMARY - LOWER LIMIT**

NATO I-TEQ					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	09:25 - 15:25 07 December 2017	0.00084	-	0.1	0.0008
Field Blanks Run 1	-	0.00036	-	-	-

WHO TEQ (Humans / Mammals)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1 <small>07 December 2017</small>	09:25 - 15:25 07 December 2017	0.00071	-	-	0.0007
Field Blanks Run 1	-	0.00035	-	-	-

WHO TEQ (Fish)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	09:25 - 15:25 07 December 2017	0.00073	-	-	0.0007
Field Blanks Run 1	-	0.00026	-	-	-

WHO TEQ (Birds)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	09:25 - 15:25 07 December 2017	0.0016	-	-	0.0016
Field Blanks Run 1	-	0.00073	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS ANALYSIS SUMMARY - RUN 1**

NATO I-TEQ & WHO TEQ (Humans / Mammals)					
Congener	Result ng	NATO I-TEQ ng	WHO TEQ Humans / Mammals ng	Extraction Recovery	
				Actual %	Permitted %
<b>Dioxins</b>					
2378 Tetra CDD	< 0.002	0.002	0.002	98	50 - 130
12378 Penta CDD	< 0.002	0.001	0.002	106	50 - 130
123478 Hexa CDD	< 0.003	0.0003	0.0003	95	50 - 130
123678 Hexa CDD	< 0.0033	0.00033	0.00033	94	50 - 130
123789 Hexa CDD	0.003	0.0003	0.0003		
1234678 Hepta CDD	0.025	0.00025	0.00025	102	50 - 130
OCDD Octa CDD	0.048	0.000048	0.0000144	94	20 - 150
<b>Total -Dioxins</b>	<b>0.0863</b>	<b>0.00423</b>	<b>0.00519</b>		
<b>Furans</b>					
2378 Tetra CDF	0.0044	0.00044	0.00044	102	50 - 130
12378 Penta CDF	0.0032	0.00016	0.000096	0	>=50
23478 Penta CDF	0.0038	0.0019	0.00114	103	50 - 130
123478 Hexa CDF	0.0072	0.00072	0.00072	96	50 - 130
123678 Hexa CDF	0.0055	0.00055	0.00055	99	50 - 130
234678 Hexa CDF	0.0092	0.00092	0.00092	92	50 - 130
123789 Hexa CDF	0.0037	0.00037	0.00037	0	>=50
1234678 Hepta CDF	0.013	0.00013	0.00013	92	20 - 150
1234789 Hepta CDF	< 0.01	0.0001	0.0001	0	>=50
OCDF Octa CDF	< 0.01	0.00001	0.000003	95	20 - 150
<b>Total -Furans</b>	<b>0.07</b>	<b>0.00530</b>	<b>0.00447</b>		
<b>Mean Recoveries (%)</b>				<b>98</b>	
<b>Total Isomers  </b>	<b>0.1563</b>	<b>0.00953</b>	<b>0.00966</b>		
<b>Total ITEQ (&lt;LOD = 0)</b>		<b>0.00579</b>	<b>0.00493</b>		

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS ANALYSIS SUMMARY - RUN 1**

Congener	WHO TEQ (Fish) & WHO TEQ (Birds)				
	Result	WHO TEQ Fish	WHO TEQ Birds	Extraction Recovery	
				Actual	Permitted
	ng	ng	ng	%	%
<b>Dioxins</b>					
2378 Tetra CDD	< 0.002	0.002	0.002	98	50 - 130
12378 Penta CDD	< 0.002	0.002	0.002	106	50 - 130
123478 Hexa CDD	< 0.003	0.0015	0.00015	95	50 - 130
123678 Hexa CDD	< 0.0033	0.000033	0.000033	94	50 - 130
123789 Hexa CDD	0.003	0.00003	0.00003		
1234678 Hepta CDD	0.025	0.000025	0.000025	102	50 - 130
OCDD Octa CDD	0.048	-	-	94	20 - 150
<b>Total -Dioxins</b>	<b>0.0863</b>	<b>0.00559</b>	<b>0.00424</b>		
<b>Furans</b>					
2378 Tetra CDF	0.0044	0.00022	0.0044	102	50 - 130
12378 Penta CDF	0.0032	0.00016	0.000032	0	>=50
23478 Penta CDF	0.0038	0.0019	0.0038	103	50 - 130
123478 Hexa CDF	0.0072	0.00072	0.00072	96	50 - 130
123678 Hexa CDF	0.0055	0.00055	0.00055	99	50 - 130
234678 Hexa CDF	0.0092	0.00092	0.00092	92	50 - 130
123789 Hexa CDF	0.0037	0.00037	0.00037	0	>=50
1234678 Hepta CDF	0.013	0.00013	0.00013	92	20 - 150
1234789 Hepta CDF	< 0.01	0.0001	0.0001	0	>=50
OCDF Octa CDF	< 0.01	0.000001	0.000001	95	20 - 150
<b>Total -Furans</b>	<b>0.07</b>	<b>0.00507</b>	<b>0.01102</b>		
<b>Mean Recoveries (%)</b>				<b>98</b>	
<b>Total Isomers</b>	<b>0.1563</b>	<b>0.01066</b>	<b>0.01526</b>		
<b>Total ITEQ (&lt;LOD = 0)</b>		<b>0.00503</b>	<b>0.01098</b>		

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS ANALYSIS SUMMARY - FIELD BLANK RUN 1**

NATO I-TEQ & WHO TEQ (Humans / Mammals)					
Congener	Result ng	NATO I-TEQ ng	WHO TEQ Humans / Mammals ng	Extraction Recovery	
				Actual %	Permitted %
<b>Dioxins</b>					
2378 Tetra CDD	< 0.002	0.002	0.002	77	50 - 130
12378 Penta CDD	< 0.002	0.001	0.002	91	50 - 130
123478 Hexa CDD	< 0.003	0.0003	0.0003	73	50 - 130
123678 Hexa CDD	< 0.0033	0.00033	0.00033	76	50 - 130
123789 Hexa CDD	0.003	0.0003	0.0003		
1234678 Hepta CDD	0.017	0.00017	0.00017	84	50 - 130
OCDD Octa CDD	0.039	0.000039	0.0000117	84	20 - 150
<b>Total -Dioxins</b>	<b>0.0693</b>	<b>0.00414</b>	<b>0.00511</b>		
<b>Furans</b>					
2378 Tetra CDF	0.0034	0.00034	0.00034	83	50 - 130
12378 Penta CDF	< 0.002	0.0001	0.00006	0	>=50
23478 Penta CDF	< 0.002	0.001	0.0006	90	50 - 130
123478 Hexa CDF	0.004	0.0004	0.0004	79	50 - 130
123678 Hexa CDF	0.004	0.0004	0.0004	77	50 - 130
234678 Hexa CDF	0.004	0.0004	0.0004	77	50 - 130
123789 Hexa CDF	0.004	0.0004	0.0004	0	>=50
1234678 Hepta CDF	< 0.01	0.0001	0.0001	79	20 - 150
1234789 Hepta CDF	< 0.01	0.0001	0.0001	0	>=50
OCDF Octa CDF	0.015	0.000015	0.0000045	90	20 - 150
<b>Total -Furans</b>	<b>0.0584</b>	<b>0.003255</b>	<b>0.0028045</b>		
<b>Mean Recoveries (%)</b>				<b>82</b>	
<b>Total Isomers</b>	<b>0.1277</b>	<b>0.00739</b>	<b>0.00792</b>		
<b>Total ITEQ (&lt;LOD = 0)</b>		<b>0.00246</b>	<b>0.00243</b>		

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS ANALYSIS SUMMARY - FIELD BLANK RUN 1**

WHO TEQ (Fish) & WHO TEQ (Birds)					
Congener	Result	WHO TEQ Fish	WHO TEQ Birds	Extraction Recovery	
				Actual	Permitted
	ng	ng	ng	%	%
<b>Dioxins</b>					
2378 Tetra CDD	< 0.002	0.002	0.002	77	50 - 130
12378 Penta CDD	< 0.002	0.002	0.002	91	50 - 130
123478 Hexa CDD	< 0.003	0.0015	0.00015	73	50 - 130
123678 Hexa CDD	< 0.0033	0.000033	0.000033	76	50 - 130
123789 Hexa CDD	0.003	0.00003	0.00003		
1234678 Hepta CDD	0.017	0.000017	0.000017	84	50 - 130
OCDD Octa CDD	0.039	-	-	84	20 - 150
<b>Total -Dioxins</b>	<b>0.0693</b>	<b>0.00558</b>	<b>0.00423</b>		
<b>Furans</b>					
2378 Tetra CDF	0.0034	0.00017	0.0034	83	50 - 130
12378 Penta CDF	< 0.002	0.0001	0.00002	0	>=50
23478 Penta CDF	< 0.002	0.001	0.002	90	50 - 130
123478 Hexa CDF	0.004	0.0004	0.0004	79	50 - 130
123678 Hexa CDF	0.004	0.0004	0.0004	77	50 - 130
234678 Hexa CDF	0.004	0.0004	0.0004	77	50 - 130
123789 Hexa CDF	0.004	0.0004	0.0004	0	>=50
1234678 Hepta CDF	< 0.01	0.0001	0.0001	79	20 - 150
1234789 Hepta CDF	< 0.01	0.0001	0.0001	0	>=50
OCDF Octa CDF	0.015	0.0000015	0.0000015	90	20 - 150
<b>Total -Furans</b>	<b>0.0584</b>	<b>0.00307</b>	<b>0.00722</b>		
<b>Mean Recoveries (%)</b>				<b>82</b>	
<b>Total Isomers</b>	<b>0.1277</b>	<b>0.00865</b>	<b>0.01145</b>		
<b>Total ITEQ (&lt;LOD = 0)</b>		<b>0.00182</b>	<b>0.00505</b>		

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 1			Dioxins & Furans		
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>		
Barometric pressure, P <sub>b</sub>	mm Hg	757.51	CO <sub>2</sub>	%	1.57
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	1.22	O <sub>2</sub>	%	20.95
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	757.60	Total	%	22.52
			N <sub>2</sub> (100 - Total)	%	77.48
			M <sub>d</sub> = 0.44(%CO <sub>2</sub> ) + 0.32(%O <sub>2</sub> ) + 0.28(%N <sub>2</sub> )		29.09
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			<b>Molecular weight of wet gas, M<sub>s</sub></b>		
Moisture trap weight increase, V <sub>lc</sub>	g	H 0 by FTIR	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>w0</sub> ) + 18(B <sub>w0</sub> )	g/gmol	28.87
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Velocity of stack gas, V<sub>s</sub></b>		
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			Pitot tube velocity constant, K <sub>p</sub>		34.97
Volume of gas sample through gas meter, V <sub>m</sub>		7.52	Velocity pressure coefficient, C <sub>p</sub>		0.84
Gas meter correction factor, Y <sub>d</sub>		0.97198	Mean of velocity heads, DP <sub>avg</sub>	mm H <sub>2</sub> O	3.41
Mean dry gas meter temperature, T <sub>m</sub>		22.50	Mean square root of velocity heads, ÖDP		1.85
Mean pressure drop across orifice, DH	mmH <sub>2</sub> O	31.33	Mean stack gas temperature, T <sub>s</sub>	°C	43
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$		6.75	$V_s = \frac{(K_p)(C_p)(\sqrt{DP})(\sqrt{T_s + 273})}{(M_d)(P_s)}$	m/s	6.51
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>		
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.9232	Area of stack, A <sub>s</sub>	m <sup>2</sup>	0.05
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min	19.2
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)	No		<b>Total flow of stack gas, Q</b>		
% oxygen measured in gas stream, act%O <sub>2</sub>	20.95		Conversion factor (K/mm.Hg)		
% oxygen reference condition	21		$Q_{std} = \frac{(Q_a)P_s(0.3592)(1-B_{w0})}{(T_s) + 273}$	Dry	16.2
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	No O <sub>2</sub> Ref	$Q_{stdO2} = \frac{(Q_a)P_s(0.3592)(1-B_{w0})(O_2REF)}{(T_s) + 273}$	@O <sub>2</sub> ref	No O <sub>2</sub> Ref
Factor	21.0 - ref%O <sub>2</sub>		$Q_{stw} = \frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	Wet	17
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2Ref)$	m <sup>3</sup>	No O <sub>2</sub> Ref	<b>Percent isokinetic, %I</b>		
<b>Moisture content, B<sub>w0</sub></b>			Nozzle diameter, D <sub>n</sub>	mm	8.5
$B_{w0} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0200	Nozzle area, A <sub>n</sub>	mm <sup>2</sup>	56.8
		2.46	Total sampling time, q	min	360.0
<b>Moisture by FTIR</b>			%I = $\frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1-B_{w0})}$	%	100.1
			Acceptable isokinetic range 95% to 115%		Yes

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS QUALITY ASSURANCE CHECKLIST**

Leak Test Results	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable litre/min
Run 1	20.31	0.10	0.12	-355.6	1.02	Yes

Isokinetic Criterion Compliance	Isokinetic Variation %	Acceptable Isokineticity
Run 1	100.1	Yes

Acceptable isokinetic range 95% to 115%

Filtration	Filter Material	Filter Size mm	Maximum Filtration Temperature °C
Run 1	Quartz Fibre	90	120

Critical Sampling Requirement	Maximum Temperature at Condenser / Adsorber °C	Acceptable Temperature?	Maximum Temperature during storage / transit °C	Acceptable Temperature?
Run 1	15	Yes	21	Yes
Acceptance Criteria	< 20°C	-	< 25°C	-

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS SOLID & VAPOUR PHASES COMBINED**

CADMIUM & THALLIUM COMBINED					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	12:40 - 14:40 05 December 2017	0.0007	0.0005	0.05	0.0007
Field Blank	-	0.0006	-	-	-
TOTAL HEAVY METALS COMBINED					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	12:40 - 14:40 05 December 2017	0.0931	0.0016	0.5	0.10
Field Blank	-	0.0031	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

**INDIVIDUAL METALS SUMMARY - SOLID & VAPOUR PHASES COMBINED**

Metals	LOD mg/m <sup>3</sup>	Concentration mg/m <sup>3</sup>	Emission Rate g/hr	Uncertainty (%)	UKAS Accredited
Cadmium	0.00022	0.00039	0.000404	107%	✓
Thallium	0.00026	0.00027	0.000278	148%	✓
Cadmium & Thallium	0.00047	0.00065	0.000682	147%	-

Metals	LOD mg/m <sup>3</sup>	Concentration mg/m <sup>3</sup>	Emission Rate g/hr	Uncertainty (%)	UKAS Accredited
Arsenic	0.00018	0.00018	0.000190	148%	✓
Antimony	0.00018	0.00019	0.000202	197%	✓
Chromium	0.00015	0.06439	0.067314	16%	✓
Cobalt	0.00009	0.00018	0.000190	99%	✓
Copper	0.00022	0.00400	0.004179	25%	✓
Lead	0.00022	0.00184	0.001927	37%	✓
Manganese	0.00018	0.00318	0.003325	197%	✓
Nickel	0.00018	0.01869	0.019542	17%	✓
Vanadium	0.00026	0.00044	0.000460	119%	✓
Total Other Heavy Metals	0.00163	0.09310	0.097328	11%	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS - RUN 1 SUMMARY**

Metals	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>
Cadmium	0.00	0.50	0.00021	0.000006	0.41	0.00017
Thallium	0.00	0.60	0.00025	0.000006	0.03	0.00001
Cadmium & Thallium	0.00	1.10	0.00047	0.000006	0.44	0.00019
Volume Sampled m <sup>3</sup>		2.3621			2.3621	

Reference conditions are 273K, 101.3kPa without correction for water vapour

Metals	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>
Arsenic	0.00017	0.400	0.00017	0.00001	0.02871	0.00001
Antimony	0.00017	0.400	0.00017	0.00001	0.05742	0.00002
Chromium	0.00013	150.000	0.06350	0.00002	2.09991	0.00089
Cobalt	0.00008	0.400	0.00017	0.00001	0.02871	0.00001
Copper	0.00021	5.000	0.00212	0.00001	4.44260	0.00188
Lead	0.00021	3.000	0.00127	0.00001	1.35447	0.00057
Manganese	0.00017	6.900	0.00292	0.00001	0.61384	0.00026
Nickel	0.00017	32.000	0.01355	0.00001	12.15520	0.00515
Vanadium	0.00025	1.000	0.00042	0.00001	0.03862	0.00002
Total Other Heavy Metals	0.00157	199.10000	0.08429	0.00007	20.81948	0.00881
Volume Sampled m <sup>3</sup>		2.3621			2.3621	

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS - BLANK SUMMARY**

Metals	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>
Cadmium	0.00021	0.50	0.00021	0.00001	0.23500	0.00010
Thallium	0.00021	0.60	0.00025	0.00001	0.02350	0.00001
Cadmium & Thallium	0.00042	1.10	0.00047	0.00001	0.25850	0.00011
Volume Sampled m <sup>3</sup>		2.3621			2.3621	

Reference conditions are 273K, 101.3kPa without correction for water vapour

Metals	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>
Arsenic	0.00017	0.40000	0.00017	0.00001	0.02350	0.00001
Antimony	0.00017	0.40000	0.00017	0.00001	0.02350	0.00001
Chromium	0.00013	0.60000	0.00025	0.00002	0.23500	0.00010
Cobalt	0.00008	0.20000	0.00008	0.00001	0.02350	0.00001
Copper	0.00021	0.50000	0.00021	0.00001	1.26900	0.00054
Lead	0.00021	0.70000	0.00030	0.00001	0.77550	0.00033
Manganese	0.00017	0.40000	0.00017	0.00001	0.37600	0.00016
Nickel	0.00017	0.50000	0.00021	0.00001	0.16450	0.00007
Vanadium	0.00025	0.60000	0.00025	0.00001	0.02350	0.00001
Total Other Heavy Metals	0.00157	4.30000	0.00182	0.00007	2.91400	0.00123
Volume Sampled m <sup>3</sup>		2.3621			2.3621	

Reference conditions are 273K, 101.3kPa without correction for water vapour



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**MERCURY SUMMARY - PARTICULATE & VAPOUR PHASES COMBINED**

Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	12:40 - 14:40 05 December 2017	0.00027	0.00022	0.05	0.00028
Field Blank	-	0.00027	-	-	-

Mercury	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mean mg/m <sup>3</sup>	Lab Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mean mg/m <sup>3</sup>	Lab Result ug	Concentration mg/m <sup>3</sup>
Run 1	0.00021	0.50	0.00021	0.00001	0.13	0.00005
Volume Sampled m <sup>3</sup>		2.3621			2.3621	
Field Blank	-	0.50	0.00021	-	0.14	0.0001
Volume Sampled m <sup>3</sup>		2.3621			2.3621	

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 1			Cd, Tl, Heavy Metals & Mercury		
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>		
Barometric pressure, P <sub>b</sub>	mm Hg	765.0	CO <sub>2</sub>	%	1.57
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	1.2	O <sub>2</sub>	%	20.95
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	765.1	Total	%	22.52
			N <sub>2</sub> (100 -Total)	%	77.48
			M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )		29.09
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			<b>Molecular weight of wet gas, M<sub>s</sub></b>		
Moisture trap weight increase, V <sub>lc</sub>	g	H 0 by FTIR	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	g/gmol	28.82
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Velocity of stack gas, V<sub>s</sub></b>		
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			Pitot tube velocity constant, K <sub>p</sub>		34.97
Volume of gas sample through gas meter, V <sub>m</sub>		2.506	Velocity pressure coefficient, C <sub>p</sub>		0.84
Gas meter correction factor, Y <sub>d</sub>		0.97198	Mean of velocity heads, DP <sub>avg</sub>	mm H <sub>2</sub> O	3.62
Mean dry gas meter temperature, T <sub>m</sub>		18.46	Mean square root of velocity heads, ÖDP		1.90
Mean pressure drop across orifice, DH	mm	33.56	Mean stack gas temperature, T <sub>s</sub>	°C	33
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$		2.30	$V_s = \frac{(K_p)(C_p)(\sqrt{DP})(\sqrt{T_s + 273})}{(M_d)(P_s)}$	m/s	6.58
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>		
V <sub>mstw</sub> = V <sub>mstd</sub> + V <sub>wstd</sub>	m <sup>3</sup>	2.3621	Area of stack, A <sub>s</sub>	m <sup>2</sup>	0.05
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b>			Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min	19.4
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)	No		<b>Total flow of stack gas, Q</b>		
% oxygen measured in gas stream, act%O <sub>2</sub>	21.0		Conversion factor (K/mm.Hg)		0.3592
% oxygen reference condition	21		Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	Dry	17.0
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	No O <sub>2</sub> Ref	Q <sub>stdO<sub>2</sub></sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s) + 273}$	@O <sub>2</sub> ref	No O <sub>2</sub> Ref
Factor	$\frac{21.0 - ref\%O_2}{21.0 - ref\%O_2}$	No O <sub>2</sub> Ref	Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	Wet	17.4
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	No O <sub>2</sub> Ref	<b>Percent isokinetic, %I</b>		
<b>Moisture content, B<sub>wo</sub></b>			Nozzle diameter, D <sub>n</sub>	mm	8.50
B <sub>wo</sub> = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0246	Nozzle area, A <sub>n</sub>	mm <sup>2</sup>	56.75
		2.46	Total sampling time, q	min	120
<b>Moisture by FTIR</b>			%I = $\frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1 - B_{wo})}$	%	97.7
		2.463143963	Acceptable isokinetic range 95% to 115%		
					Yes

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS QA CHECKLIST**

Leak Test Results	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable litre/min
Run 1	20.3	0.10	0.20	-355.6	0.41	Yes

Isokinetic Criterion Compliance	Isokinetic Variation %	Acceptable Isokineticity
Run 1	97.7	Yes

Filtration / Temp	Filter Material	Filter Size mm	Maximum Filtration Temperature °C	Maximum storage / transit Temperature °C
Run 1	Quartz Fibre	47	180	21

Metals	Type of Absorbers - Metals	Absorption Solutions - Metals
Run 1	PTFE	3.3% Nitric Acid, 1.5% Hydrogen Peroxide

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS ABSORPTION EFFICIENCY**

Parameter		Total ug	3rd Absorber ug	Absorption Efficiency (%)	Required %	Pass / Fail
Cadmium	Run 1	0.913	0.17	82	90	N/A <30% ELV
Thallium	Run 1	1.542	ND	100	90	N/A <30% ELV
Arsenic	Run 1	0.429	ND	100	90	N/A <30% ELV
Antimony	Run 1	0.457	0.02	96	90	N/A <30% ELV
Chromium	Run 1	152.100	0.80	99	90	N/A <30% ELV
Cobalt	Run 1	0.429	ND	100	90	N/A <30% ELV
Copper	Run 1	9.443	3.77	60	90	N/A <30% ELV
Lead	Run 1	4.354	0.56	87	90	N/A <30% ELV
Manganese	Run 1	7.514	0.24	97	90	N/A <30% ELV
Nickel	Run 1	44.155	11.89	73	90	N/A <30% ELV
Vanadium	Run 1	1.03862	0.02	98	90	N/A <30% ELV

Parameter		Total ug	5th Absorber ug	Absorption Efficiency	Required	Pass / Fail
Mercury	Run 1	0.63	ND	100	95	N/A <30% ELV

HYDROGEN CHLORIDE SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	11:05 - 12:05 05 December 2017	0.30	0.0007	20	0.29
Field Blank	-	0.0019	-	-	-

Please note figures in bold italic font are at the limit of detection

Reference conditions are 273K, 101.3kPa without correction for water vapour

#### HYDROGEN CHLORIDE QUALITY ASSURANCE CHECKLIST

Leak Test Results	Mean Sampling Rate l/min	Pre sampling leak rate l/min	Post sampling leak rate l/min	Acceptable leak rate l/min	Leak Tests Acceptable?
Run 1	18.9	0.12	0.20	0.38	Yes

	Filter Material	Filter Size mm	Max. Filtration Temp. °C	Max. Storage / Transit Temp. °C	Type of Absorbers	Absorption Solutions
Run 1	Quartz Fibre	47	160	21	Glass	HPLC Water

#### HYDROGEN CHLORIDE ABSORPTION EFFICIENCY

Parameter	Total ug	IMP C ug	Absorption Efficiency %	Acceptable Absorption Efficiency %	Absorption Efficiency Acceptable ?
Run 1	333.062	8.162	98	95	Yes

ND - None Detected

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS 1			Hydrogen Chloride	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Velocity of stack gas, V<sub>s</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	765	Pitot tube velocity constant, K <sub>p</sub>	34.97
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	1	Velocity pressure coefficient, C <sub>p</sub>	0.84
P <sub>s</sub> = P <sub>b</sub> + (P <sub>static</sub> )	mm Hg	765	Mean of velocity heads, DP <sub>avg</sub>	mm H <sub>2</sub> O
13.6			Mean square root of velocity heads, ÖDP	1.83
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			Mean stack gas temperature, T <sub>s</sub>	
Moisture trap weight increase, Vlc	g	H 0 by FTIR		°C
V <sub>wstd</sub> = (0.001246)(V <sub>lc</sub> )	m <sup>3</sup>	-	V <sub>s</sub> = $\frac{(K_p)(C_p)(\ddot{O}DP)(\ddot{O}(T_s + 273))}{(M_s)(P_s)}$	m/s
6.5				
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		1.1690	Area of stack, A <sub>s</sub>	m <sup>2</sup>
Gas meter correction factor, Y <sub>d</sub>		0.97198	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min
Mean dry gas meter temperature, T <sub>m</sub>		13.33		19
Mean pressure drop across orifice, DH	mmH <sub>2</sub> O	29.15	<b>Dry total flow of stack gas, Q<sub>std</sub></b>	
V <sub>mstd</sub> = $\frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$		1.09	Conversion factor (K/mm.Hg)	0.3592
			Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	m <sup>3</sup> /min
				16
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			<b>Wet total flow of stack gas, Q<sub>stw</sub></b>	
V <sub>mstw</sub> = V <sub>mstd</sub> + V <sub>wstd</sub>	m <sup>3</sup>	1.1211	Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	m <sup>3</sup> /min
				16
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b>			<b>Dry total flow of stack gas at X% O<sub>2</sub>, Q<sub>stdO<sub>2</sub></sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Q <sub>stdO<sub>2</sub></sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s) + 273}$	m <sup>3</sup> /min
% oxygen measured in gas stream, act%O <sub>2</sub>		20.9		No O <sub>2</sub> Ref
% oxygen reference condition		21	<b>Percent isokinetic, %I</b>	
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	No O <sub>2</sub> Ref	Nozzle diameter, D <sub>n</sub>	mm
Factor	21.0 - ref%O <sub>2</sub>		Nozzle area, A <sub>n</sub>	mm <sup>2</sup>
V <sub>mstd@X%oxygen</sub> = (V <sub>mstd</sub> )(O <sub>2</sub> Ref)		No O <sub>2</sub> Ref	Total sampling time, q	min
			%I = $\frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1 - B_{wo})}$	%
				99
<b>Moisture content, B<sub>wo</sub></b>			Acceptable isokinetic range 95% to 115%	
B <sub>wo</sub> = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.0246		Yes
		2.46	<b>Hydrogen Chloride Concentration, C</b>	
<b>Moisture by FTIR</b>			Mass collected, M	
		2.463143963	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$	ug
<b>Molecular weight of dry gas, M<sub>d</sub></b>			C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$	
CO <sub>2</sub>		1.57		mg/m <sup>3</sup>
O <sub>2</sub>		20.9		0.297
Total		22.47		0.305
N <sub>2</sub> (100 - Total)		77.53		No O <sub>2</sub> Ref
M <sub>d</sub> = 0.44(%CO <sub>2</sub> ) + 0.32(%O <sub>2</sub> ) + 0.28(%N <sub>2</sub> )		29.09	C <sub>dry@X%O<sub>2</sub></sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$	
<b>Molecular weight of wet gas, M<sub>s</sub></b>			<b>Hydrogen Chloride Emission Rates, E</b>	
M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	g/gmol	28.8	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	g/hr
				0.29

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

HYDROGEN FLUORIDE SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	15:15 - 16:15 05 December 2017	<b>0.03</b>	0.01	2	<b>0.03</b>
Field Blank	-	0.024	-	-	-

Please note figures in bold italic font are at the limit of detection

Reference conditions are 273K, 101.3kPa without correction for water vapour

**HYDROGEN FLUORIDE QUALITY ASSURANCE CHECKLIST**

Leak Test Results	Mean Sampling Rate l/min	Pre sampling leak rate l/min	Post sampling leak rate l/min	Acceptable leak rate l/min	Leak Tests Acceptable?
Run 1	3.0	0.02	0.03	0.06	Yes

	Filter Material	Filter Size mm	Max. Filtration Temp. °C	Max. Storage / Transit Temp. °C	Type of Absorbers	Absorption Solutions
Run 1	Quartz Fibre	47	150	21	PE	0.1N Sodium Hydroxide

**HYDROGEN FLUORIDE ABSORPTION EFFICIENCY**

Parameter	Total ug	IMP C ug	Absorption Efficiency %	Acceptable Absorption Efficiency %	Absorption Efficiency Acceptable ?
Run 1	ND	ND	100	95	Yes

ND - None Detected

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**COMBUSTION GAS SUMMARY**

Test	Sampling Times	Concentration mg/m <sup>3</sup>	Analysis Areas	Interference (%) *	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Oxides of Nitrogen	11:30 - 15:30 06 December 2017	5.7	1875 - 2130 / 2700 - 2950	3.48	3.483	400	5.59
Sulphur Dioxide	11:30 - 15:30 06 December 2017	5.7	1100 - 1380	3.8	0.371	100	5.59
Carbon Monoxide	11:30 - 15:30 06 December 2017	3.5	2000 - 2200 / 2540 - 2590	1.8	0.075	150	3.42
Nitrous Oxide	11:30 - 15:30 06 December 2017	0.4	2100 - 2223 / 2540 - 2600	2.1	0.277	-	0.34

\*M22 Specifies interference must be <5%.

Reference conditions are 273K, 101.3kPa without correction for water vapour

\*M22 Specifies interference must be <5%.

**FTIR CALIBRATION CHECKS**


Pre - Sampling Checks - System			Date of Checks	06 December 2017			Time of Checks	10:30	
Post Sampling Checks - System			Date of Checks	06 December 2017			Time of Checks	15:35	
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift	
CO	-0.01	-0.10	-0.09	78.0	80.0	2.61	80.3	0.37	
NO <sub>x</sub>	1.53	0.00	-1.53	79.8	79.3	-0.63	80.1	1.06	
SO <sub>2</sub>	0.08	0.21	0.43	404.0	405.3	0.33	404.0	-0.33	
N <sub>2</sub> O	0.01	0.02	0.10	41.8	42.2	0.88	41.7	-1.19	

Note - Methane was used as a surrogate span check for moisture. All other surrogates are listed in the individual measurement uncertainty budgets. Acceptance criteria for initial span check variation is +/-5% of certified reading for all gases, except HCl and NH<sub>3</sub> which are +/- 10% of certified reading. Acceptance criteria for % zero drift across the test is +/-2% of range for all gases. Acceptance criteria for % span drift across the test is +/-5% for all gases, except very reactive gases, such as HCl and NH<sub>3</sub> which are exempt. M22 also states that if the gas with the narrowest peak width (Methane) has to be drift corrected and that correction should also apply to all gases.




APPENDIX 2 - Summaries, Calculations, Raw Data and Charts


**OXIDES OF NITROGEN EMISSIONS CHART**




**SULPHUR DIOXIDE EMISSIONS CHART**



**CARBON MONOXIDE EMISSIONS CHART**



### NITROUS OXIDE EMISSIONS CHART



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

### PRELIMINARY STACK SURVEY

Stack Characteristics		
Stack Diameter / Depth, D	0.25	m
Stack Width, W	-	m
Stack Area, A	0.05	m <sup>2</sup>
Average stack gas temperature	50	°C
Stack static pressure	0.012	kPa
Barometric Pressure	102	kPa

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m <sup>3</sup> p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m <sup>3</sup> pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m <sup>3</sup> pi
CO <sub>2</sub>	44	1.963059	0.161847	0.001618	0.003177	0.157860	0.001579	0.003099
O <sub>2</sub>	32	1.427679	16.134135	0.161341	0.230344	15.736728	0.157367	0.224670
N <sub>2</sub>	28	1.249219	83.704018	0.837040	1.045647	81.642268	0.816423	1.019891
H <sub>2</sub> O	18	0.803070	-	-	-	2.463144	0.024631	0.019781

Where:  $p = M / 22.41$      $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), $P_{STD}$	1.2792	kg/m <sup>3</sup>
Wet Density (STP), $P_{STW}$	1.2674	kg/m <sup>3</sup>
Dry Density (Actual), $P_{Actual}$	1.0888	kg/m <sup>3</sup>
Average Wet Density (Actual), $P_{ActualW}$	1.079	kg/m <sup>3</sup>

Where:

$$P_{STD} = \text{sum of component concentrations, kg/m}^3 \text{ (not including water vapour)}$$

$$P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$$

$$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$$

$$P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$$

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

Date of Survey	05 December 2017
Time of Survey	10:40
Velocity Measurement Device:	S-Type Pitot

Sampling Line A								
Traverse Point	Distance into duct (m)	DP pt mmH <sub>2</sub> O (average of 3 readings)	DP pt Pa (average of 3 readings)	Temp °C	Velocity m/s	Volumetric Flow Rate (actual) m <sup>3</sup> /s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.13	3.3	33	50	6.5	0.32	-	<15
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
Mean	-	3.3	33	50	6.5	0.32	-	-

Sampling Line B								
Traverse Point	Distance into duct (m)	DP pt mmH <sub>2</sub> O (average of 3 readings)	DP pt Pa (average of 3 readings)	Temp °C	Velocity m/s	Volumetric Flow Rate (actual) m <sup>3</sup> /s	O <sub>2</sub> % Vol	Angle of Swirl °
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	-	-

**PRELIMINARY STACK SURVEY QUALITY ASSURANCE CHECKLIST**

PITOT LEAK CHECK								
Run	Pre Traverse Leak Rate				Post Traverse Leak Rate			
	Start Value Pa	End Value Pa	Difference %	Outcome	Start Value Pa	End Value Pa	Difference %	Outcome
Run 1	164	158	3.7	Pass	182	176	3.3	Pass

To complete a compliant pitot leak check a pressure of over 80 mmH<sub>2</sub>O (or 800 Pa) is applied and the pressure drop monitored over 5 mins. A drop of less than 5% must be observed.

S-Type Pitot Stagnation Check				
Run	Stagnation (Pa)	Reference (Pa)	Difference (Pa)	Outcome (Permitted +/- 10 Pa)
Run 1	12	10	2.0	Pass

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	33	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	6.5	m/s	-	-
Highest Gas Velocity	6.5	m/s	-	-
Ratio of Gas Velocities	1.0	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-e) \times O(2 * DP_{pt} / P_{ActualW})$		
<b>Where:</b>		
$K_{pt}$ = Pitot tube calibration coefficient		
(1-e) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, Va	6.5	m/s

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	50	0	°C
Total Pressure	102.012	101.3	kPa
Oxygen	21.0	21	%
Moisture	2.46	2.46	%
Pitot tube calibration coefficient, $K_{pt}$	0.84		

Gas Volumetric Flowrate	Result	Units
Average Stack Gas Velocity (Va)	6.51	m/s
Stack Area (A)	0.05	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$	1150	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$	979	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$	955	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$	979	m <sup>3</sup> /hr

**Where:**

$$Q_{Actual} = Va \times A \times 3600$$

$$Q_{STP} = Q (Actual) \times (Ts / Ta) \times (Pa / Ps) \times 3600$$

$$Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma)) \times 3600$$

$$Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$$

**Nomenclature:**

Ts = Absolute Temperature, Standard Conditions, 273 K

Ps = Absolute Pressure, Standard Conditions, 101.3 kPa

Ta = Absolute Temperature, Actual Conditions, K

Pa = Absolute Pressure, Actual Conditions, kPa

Ma = Water vapour, Actual Conditions, % Vol

Ms = Water vapour, Reference Conditions, % Vol

O<sub>2a</sub> = Oxygen, Actual Conditions, % Vol

O<sub>2s</sub> = Oxygen, Reference Conditions, % Vol


APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

	Value	Units
Stack Depth	0.25	m
Stack Width	-	m
Area	0.05	m <sup>2</sup>

Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack	Units
A	50	0.13	m

Isokinetic Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	50.0	0.13	< 15
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-



- Isokinetic sampling point
- Isokinetic sampling points not used
- Non Isokinetic/Gases sampling point

**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - DIOXINS & FURANS**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Leak %
<b>MU required</b>	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 2%
Run 1	0.001	2.0	0.50	1.0	N/A	-
as a %	0.01	0.7	0.49	1.0	N/A	0.59
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	O2 Correction -	Mass of Dioxin & Furan ng	Leak ng/m <sup>3</sup>	Laboratory analysis -	Combined uncertainty
Run 1	6.3779	1.0	0.1563	0.0000047	-	-
MU as ng/m <sup>3</sup>	0.00002	-	0.0009	0.0000047	0.0001	<b>0.0010</b>
MU as %	1.3051	-	67.0505	0.3411	7.50	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.002</b>	<b>ng/m<sup>3</sup></b>	<b>140.8</b>	<b>%</b>
---	--------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - CADMIUM & THALLIUM**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in impinger mg	Leak %
<b>MU required</b>	<b>&lt;=2%</b>	<b>&lt;2.5 k</b>	<b>&lt;=1%</b>	<b>&lt;=1%</b>	<b>&lt;=5%</b>	<b>&lt;=5%</b>	<b>&lt;=2%</b>
Run 1	0.001	2.0	0.50	1.0	0.1	0.00005	-
as a %	0.04	0.69	0.49	1.0	-	3.00	0.99
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	O2 Correction -	Mass of Cadmium & Thallium mg	Leak mg/m <sup>3</sup>	Lab Uncertainty mg	Combined uncertainty
Run 1	2.2304	-	1.5416	0.000004	-	-
MU as mg	0.000009	-	0.0005	0.000004	0.00003	<b>0.0005</b>
MU as %	1.3087	-	73.2177	0.5689	5.00000	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.0010</b>	<b>mg/m<sup>3</sup></b>	<b>146.80</b>	<b>%</b>
---	---------------	-------------------------	---------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - HEAVY METALS**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in impinger mg	Leak %
<b>MU required</b>	<b>&lt;=2%</b>	<b>&lt;2.5 k</b>	<b>&lt;=1%</b>	<b>&lt;=1%</b>	<b>&lt;=5%</b>	<b>&lt;=5%</b>	<b>&lt;=2%</b>
Run 1	0.001	2.0	0.50	1.0	0.10	0.0022	-
as a %	0.04	0.73	0.49	1.0	-	3.00	0.99
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	O2 Correction -	Mass of Heavy Metals mg	Leak mg/m <sup>3</sup>	Lab Uncertainty mg	Combined uncertainty
Run 1	2.3812	-	219.9195	0.0005	-	-
MU as mg/m <sup>3</sup>	0.0012	-	0.0016	0.0005	0.00466	<b>0.0051</b>
MU as %	1.3335	-	1.7542	0.5689	5.00000	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.01</b>	<b>mg/m<sup>3</sup></b>	<b>10.99</b>	<b>%</b>
---	-------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MERCURY**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in impinger mg	Leak %
<b>MU required</b>	<b>&lt;=2%</b>	<b>&lt;2.5 k</b>	<b>&lt;=1%</b>	<b>&lt;=1%</b>	<b>&lt;=5%</b>	<b>&lt;5%</b>	<b>&lt;=2%</b>
Run 1	0.001	2.0	0.50	1.0	0.10	0.000009	-
as a %	0.04	0.7	0.49	1.0	-	3.00	0.99
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	O2 Correction	Mass of Mercury mg	Leak mg/m <sup>3</sup>	Lab Uncertainty mg	Combined
Run 1	2.2304	-	0.6276	0.0000015	-	-
MU as mg/m <sup>3</sup>	0.000003	-	0.0002	0.0000015	0.00001	<b>0.0002</b>
MU as %	1.3087	-	86.5838	0.5689	5.00000	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.00046</b>	<b>mg/m<sup>3</sup></b>	<b>173.48</b>	<b>%</b>
---	----------------	-------------------------	---------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - ISOKINETIC HYDROGEN CHLORIDE**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in impinger mg	Limit of Detection % by mass	Leak %
<b>MU required</b>	<b>&lt;=2%</b>	<b>&lt;2.5 k</b>	<b>&lt;=1%</b>	<b>&lt;=1%</b>	<b>&lt;=5%</b>	<b>&lt;5%</b>	<b>≤ 5% of ELV</b>	<b>&lt;=2%</b>
Run 1	1.121	286.33	102.12	1.0	-	0.0082	0.00201	-
as a %	0.09	0.70	0.49	1.0	-	3.00	0.04	1.06
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of Hydrogen Chloride mg	O2 Correction -	Leak mg/m <sup>3</sup>	Lab Uncertainty mg	Combined uncertainty
Run 1	1.078	0.0020	-	0.0018	-	-
MU as mg/m <sup>3</sup>	0.0039	0.0090	-	0.0018	0.0143	<b>0.0174</b>
MU as %	1.3177	3.0276	-	0.6097	4.8	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>11.72</b>	<b>%</b>
---	-------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - NON-ISOKINETIC HYDROGEN FLUORIDE**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in impinger mg	Limit of Detection % by mass	Leak %
<b>MU required</b>	<b>&lt;=2%</b>	<b>&lt;2.5 k</b>	<b>&lt;=1%</b>	<b>&lt;=1%</b>	<b>&lt;=5%</b>	<b>&lt;5%</b>	<b>≤ 5% of ELV</b>	<b>&lt;=2%</b>
Run 1	0.00006	2.000	0.500	1.000	0.100	0.001	0.00017	-
as a %	0.033	0.694	0.439	1.000	-	3.000	3.021	1.000
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of Hydrogen Fluoride mg	O2 Correction -	Leak mg/m <sup>3</sup>	Lab Uncertainty mg	Combined uncertainty
Run 1	0.1923	0.0057	-	0.0002	-	-
MU as mg/m <sup>3</sup>	0.0004	0.0009	-	0.0002	0.0019	<b>0.0022</b>
MU as %	1.2944	3.0207	-	0.5774	6.1	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.004</b>	<b>mg/m<sup>3</sup></b>	<b>13.91</b>	<b>%</b>
---	--------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXIDES OF NITROGEN**

Actual Measured Concentration	5.71	mg/m <sup>3</sup>
Measured Concentration at Reference Conditions	5.71	mg/m <sup>3</sup>
Emission Limit Value	400	mg/m <sup>3</sup>
Instrument Range	205	mg/m <sup>3</sup>
Check Gas Concentration (Nitric Oxide was used as a Surrogate)	106.93	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	1.900	<2%	Yes
Zero drift (calculated from start and end readings)	-1.530	<5%	Yes
Span drift (calculated from start and end readings).	1.059	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	1.280	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.200	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	0.270	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.001	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	3.480	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	1.230	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	mg/m <sup>3</sup>
Uncertainty of linearity (lack of fit) $U_{fit}$	2.249
Uncertainty of zero drift $U_{0,dr}$	-1.811
Uncertainty of span drift $U_{s,dr}$	1.254
Uncertainty of volume or pressure flow dependence $U_{spress}$	1.515
Uncertainty in Ambient Temperature $U_{temp}$	0.398
Uncertainty in Voltage $U_{volt}$	0.001
Uncertainty of interferents $U_i$	4.118
Uncertainty of Repeatability $U_r$	2.522
Uncertainty of Certified Reference Material $U_{cal}$	0.617

Measurement Uncertainty	mg/m <sup>3</sup>
Combined uncertainty	6.01
Expanded uncertainty at a 95% Confidence Interval	12.01

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	210.37
Expressed as a % of the Measured Concentration at Reference Conditions	210.37
Expressed as a % of the Emission Limit Value	3.00

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - SULPHUR DIOXIDE BY FTIR**

Actual Measured Concentration	5.71	mg/m <sup>3</sup>
Measured Concentration at Reference Conditions	5.71	mg/m <sup>3</sup>
Emission Limit Value	100	mg/m <sup>3</sup>
Instrument Range	86	mg/m <sup>3</sup>
Check Gas Concentration	1155.44	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	0.800	<2%	Yes
Zero drift (calculated from start and end readings)	0.433	<5%	Yes
Span drift (calculated from start and end readings).	-0.329	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	1.280	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.200	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	0.140	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.001	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	3.780	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.620	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	mg/m <sup>3</sup>
Uncertainty of linearity (lack of fit) $U_{fit}$	0.396
Uncertainty of zero drift $U_{0,dr}$	0.215
Uncertainty of span drift $U_{s,dr}$	-0.163
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.634
Uncertainty in Ambient Temperature $U_{temp}$	0.121
Uncertainty in Voltage $U_{volt}$	0.0005
Uncertainty of interferents $U_i$	1.872
Uncertainty of Repeatability $U_r$	0.532
Uncertainty of Certified Reference Material $U_{cal}$	6.671

Measurement Uncertainty	mg/m <sup>3</sup>
Combined uncertainty	7.00
Expanded uncertainty at a 95% Confidence Interval	13.99

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	245.13
Expressed as a % of the Measured Concentration at Reference Conditions	245.13
Expressed as a % of the Emission Limit Value	13.99

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - CARBON MONOXIDE BY FTIR**

Actual Measured Concentration	3.49	mg/m <sup>3</sup>
Measured Concentration at Reference Conditions	3.49	mg/m <sup>3</sup>
Emission Limit Value	150	mg/m <sup>3</sup>
Instrument Range	125	mg/m <sup>3</sup>
Check Gas Concentration	97.50	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	0.950	<2%	Yes
Zero drift (calculated from start and end readings)	-0.090	<5%	Yes
Span drift (calculated from start and end readings).	0.371	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	-0.570	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.050	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	0.070	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.001	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	1.760	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.330	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	mg/m <sup>3</sup>
Uncertainty of linearity (lack of fit) $U_{fit}$	0.686
Uncertainty of zero drift $U_{0,dr}$	-0.065
Uncertainty of span drift $U_{s,dr}$	0.268
Uncertainty of volume or pressure flow dependence $U_{spress}$	-0.411
Uncertainty in Ambient Temperature $U_{temp}$	0.062
Uncertainty in Voltage $U_{volt}$	0.001
Uncertainty of interferents $U_i$	1.270
Uncertainty of Repeatability $U_r$	0.413
Uncertainty of Certified Reference Material $U_{cal}$	0.563

Measurement Uncertainty	mg/m <sup>3</sup>
Combined uncertainty	1.68
Expanded uncertainty at a 95% Confidence Interval	3.36

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	96.23
Expressed as a % of the Measured Concentration at Reference Conditions	96.23
Expressed as a % of the Emission Limit Value	2.24

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - NITROUS OXIDE BY FTIR**

Actual Measured Concentration	0.35	mg/m <sup>3</sup>
Measured Concentration at Reference Conditions	0.35	mg/m <sup>3</sup>
Emission Limit Value	-	mg/m <sup>3</sup>
Instrument Range	20	mg/m <sup>3</sup>
Check Gas Concentration	82.11	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	1.900	<2%	Yes
Zero drift (calculated from start and end readings)	0.100	<5%	Yes
Span drift (calculated from start and end readings).	-1.186	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	1.280	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.200	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	0.270	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.001	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	2.110	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	1.230	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	mg/m <sup>3</sup>
Uncertainty of linearity (lack of fit) $U_{fit}$	0.215
Uncertainty of zero drift $U_{0,dr}$	0.011
Uncertainty of span drift $U_{s,dr}$	-0.134
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.145
Uncertainty in Ambient Temperature $U_{temp}$	0.038
Uncertainty in Voltage $U_{volt}$	0.000
Uncertainty of interferents $U_i$	0.239
Uncertainty of Repeatability $U_r$	0.241
Uncertainty of Certified Reference Material $U_{cal}$	0.474

Measurement Uncertainty	mg/m <sup>3</sup>
Combined uncertainty	0.65
Expanded uncertainty at a 95% Confidence Interval	1.31

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	372.89
Expressed as a % of the Measured Concentration at Reference Conditions	372.89
Expressed as a % of the Emission Limit Value	-

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - VELOCITY & VOLUMETRIC FLOW RATE**

Measured Velocity at Actual Conditions	6.5	m/s
Measured Volumetric Flow rate at Actual Conditions	1150	m <sup>3</sup> /hr

Performance Characteristics & Source of Value	Units	Values	Requirement	Compliant
<b>Uncertainty of Local Gas Velocity Determination</b>				
Uncertainty of pitot tube coefficient	-	0.010		
Uncertainty of mean local dynamic pressures	-	0.34		
Factor loading, function of the number of measurements.	3 readings	0.591	minimum 3	Yes
Range of measurement device	pa	1000		
Resolution	pa	1.00		
Calibration uncertainty	pa	2.44	<1% of Value or 20 Pa whichever is greater	Yes
Drift	% range	0.10		
Linearity	% range	0.06	<2% of value	Yes
<b>Uncertainty of gas density determination</b>				
Uncertainty of molar mass determination	kg/mol	0.00002		
Uncertainty of temperature measurement	K	1.65	<1% of value	Yes
Uncertainty of absolute pressure in the duct	pa	520		
Uncertainty associated with the estimate of density	-	0.007		
Uncertainty associated with the measurement of local velocity	-	0.0001		
Uncertainty associated with the measurement of mean velocity	-	0.0002		

Measurement Uncertainty - Velocity	m/s
Combined uncertainty	0.09
Expanded uncertainty at a 95% Confidence Interval	0.17

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty of Velocity at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	1.3
Expanded uncertainty at a 95% Confidence Interval	2.6

Measurement Uncertainty Volumetric Flow Rate	m <sup>3</sup> /hr
Combined uncertainty	31
Expanded uncertainty at a 95% Confidence Interval	60

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty of Volumetric Flow Rate at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	2.7
Expanded uncertainty at a 95% Confidence Interval	5.2



## END OF REPORT

*Thank you for choosing Environmental Scientifics Group for your environmental monitoring needs. We hope our services have met your requirements and that you are fully satisfied with your experience of working with us, we really do value your custom and would welcome your feedback. We would appreciate it if you could take a moment to complete a short online questionnaire so that we can improve our operations and address any areas that have not met with your expectations, by clicking on the following*

[http://www.surveymonkey.com/s/ESG\\_EnvSafetyCompliance\\_CustomerFeedback](http://www.surveymonkey.com/s/ESG_EnvSafetyCompliance_CustomerFeedback)