

# STACK EMISSIONS MONITORING REPORT



Unit 5 Crown Industrial Estate  
Kenwood Road  
Stockport  
SK5 6PH  
Tel: 0161 443 0980  
Fax: 0161 443 0989

## Your contact at SOCOTEC UK LTD

Mark Woodruff  
Business Manager - North  
Tel: 0161 443 0982  
Email: mark.woodruff@socotec.com

## Operator & Address:

CEMEX UK Materials Limited  
Grimsby Coated Stone  
Gilbey Road  
Pyewipe  
Grimsby  
Lincolnshire  
DN31 2SJ

## Permit Reference:

DEFRA Process Guidance Note: PG 3/15 (12)

## Release Point:

Coating Plant

## Sampling Date(s):

19th October 2018

|                         |                              |
|-------------------------|------------------------------|
| SOCOTEC UK Job Number:  | LNO 14547                    |
| Report Date:            | 5th November 2018            |
| Version:                | 1                            |
| Report By:              | Andy Hegarty                 |
| MCERTS Number:          | MM 03 397                    |
| MCERTS Level:           | MCERTS Level 2 - Team Leader |
| Technical Endorsements: | 1, 2, 3 & 4                  |
| Report Approved By:     | Dave Armitage                |
| MCERTS Number:          | MM 04 516                    |
| Business Title:         | MCERTS Level 2 - Team Leader |
| Technical Endorsements: | 1, 2, 3 & 4                  |
| Signature:              |                              |



1015

## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

#### Monitoring Times

#### Process Details

#### Monitoring Methods

#### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

#### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

#### Sampling and Analytical Method Deviations

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

CEMEX UK Materials Limited operates a roadstone coating process at Gromsby which is subject to DEFRA Process Guidance Note PG 3/15 (12), under the Environmental Permitting Regulations 2010.

SOCOTEC UK LTD were commissioned by CEMEX UK Materials Limited to carry out stack emissions monitoring to determine the release of prescribed pollutants from the following Plant under normal operating conditions.

The results of these tests shall be used to demonstrate compliance with a set of emission limit values for prescribed pollutants as specified in the Plant's DEFRA Process Guidance Note, PG 3/15 (12).

#### **Plant**

Coating Plant

#### **Operator**

CEMEX UK Materials Limited  
Grimsby Coated Stone  
Gilbey Road  
Pyewipe  
Grimsby  
Lincolnshire  
DN31 2SJ

DEFRA Process Guidance Note: PG 3/15 (12)

#### **Stack Emissions Monitoring Test House**

SOCOTEC UK - Stockport Laboratory  
Unit 5 Crown Industrial Estate  
Kenwood Road  
Stockport  
SK5 6PH  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.  
MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.  
This test report shall not be reproduced, except in full, without written approval of SOCOTEC UK LTD.

## EXECUTIVE SUMMARY

| EMISSIONS SUMMARY                                |                    |        |                            |       |                          |
|--|--------------------|--------|----------------------------|-------|--------------------------|
| Parameter  | Units              | Result | Calculated Uncertainty +/- | Limit | MCERTS accredited result |
| Total Particulate Matter                         | mg/m <sup>3</sup>  | 30     | 1.2                        | 50    | ✓                        |
| Particulate Emission Rate                        | g/hr               | 463    | 18.5                       | -     |                          |
| Moisture   | %                  | 2.6    | 0.09                       | -     | ✓                        |
| Stack Gas Temperature                            | °C                 | 78     | -                          | -     |                          |
| Stack Gas Velocity                               | m/s                | 19.3   | 0.49                       | -     |                          |
| Gas Volumetric Flow Rate (Actual)                | m <sup>3</sup> /hr | 19667  | 1019                       | -     | ✓                        |
| Gas Volumetric Flow Rate (STP, Wet)              | m <sup>3</sup> /hr | 15524  | 804                        | -     |                          |
| Gas Volumetric Flow Rate (STP, Dry)              | m <sup>3</sup> /hr | 15120  | 783                        | -     |                          |
| Gas Volumetric Flow Rate at Reference Conditions | m <sup>3</sup> /hr | 15524  | 804                        | -     |                          |

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from the preliminary survey. Mass emissions for non isokinetic tests are calculated using these values. For all isokinetic testing the mass emission is calculated using test specific flow data and not the above values.

Reference conditions are 273K, 101.3kPa without correction for water vapour

## EXECUTIVE SUMMARY

| MONITORING TIMES               |                  |                |                   |
|--------------------------------|------------------|----------------|-------------------|
| Parameter                      | Sampling Date(s) | Sampling Times | Sampling Duration |
| Total Particulate Matter Run 1 | 19 October 2018  | 08:29 - 09:01  | 32 minutes        |
| Total Particulate Matter Run 2 | 19 October 2018  | 09:15 - 09:47  | 32 minutes        |
| Preliminary Stack Traverse     | 19 October 2018  | 08:12          | -                 |

## EXECUTIVE SUMMARY

### PROCESS DETAILS

| Parameter                                     | Process Details   |
|---|-------------------|
| Description of process                        | Roadstone Coating |
| Continuous or batch                           | Continuous        |
| Product Details                               | 6mm, 10mm & 20mm  |
| Part of batch to be monitored (if applicable) | When mixing       |
| Normal load, throughput or continuous rating  | 30 - 40t/hr       |
| Fuel used during monitoring                   | Kerosine          |
| Abatement                                     | Bag Filter        |
| Plume Appearance                              | Plume Visible     |

## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by SOCOTEC UK is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2.

| MONITORING METHODS      |   |                                      |                    |                                |                                |                           |
|-------------------------|---|--------------------------------------|--------------------|--------------------------------|--------------------------------|---------------------------|
| Species                 | Method<br>Standard Reference Method /<br>Alternative Method | SOCOTEC UK<br>Technical<br>Procedure | UKAS Lab<br>Number | MCERTS<br>Accredited<br>Method | Limit of<br>Detection<br>(LOD) | Calculated<br>MU<br>+/- % |
| TPM                     | SRM - BS EN 13284-1   | AE 104                               | 1015               | Yes                            | 0.46 mg/m <sup>3</sup>         | 4%                        |
| H <sub>2</sub> O        | SRM - BS EN 14790   | AE 105                               | 1015               | Yes                            | 0.02%                          | 3.4%                      |
| Velocity                | SRM - BS EN ISO 16911-1                                     | AE 154                               | 1015               | Yes                            | 5 Pa                           | 2.5%                      |
| Volumetric Flow<br>Rate | SRM - BS EN ISO 16911-1                                     | AE 154                               | 1015               | Yes                            | -                              | 5.2%                      |

BS EN 14790 has been validated over a range of 4 - 40%. It is however the preferred method of the Environment Agency for concentrations below 4%

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

| SAMPLING METHODS WITH SUBSEQUENT ANALYSIS |                      |                      |                 |                              |                        |                         |                |
|---|----------------------|----------------------|-----------------|------------------------------|------------------------|-------------------------|----------------|
| Species                                   | Analytical Technique | Analytical Procedure | UKAS Lab Number | UKAS Accredited Lab Analysis | Analysis Lab           | Sample Archive Location | Archive Period |
| TPM                                       | Gravimetric          | AE 106               | 1015            | Yes                          | SOCOTEC UK (Stockport) | SOCOTEC UK (Stockport)  | 8 Weeks        |

| ON-SITE TESTING  |                      |                      |                 |                            |                        |                       |                |
|------------------|----------------------|----------------------|-----------------|----------------------------|------------------------|-----------------------|----------------|
| Species          | Analytical Technique | Analytical Procedure | UKAS Lab Number | MCERTS Accredited Analysis | Laboratory             | Data Archive Location | Archive Period |
| H <sub>2</sub> O | Gravimetric          | AE 105               | 1015            | Yes                        | SOCOTEC UK (Stockport) | -                     | -              |



## EXECUTIVE SUMMARY

| SAMPLING LOCATION                              |       |       |             |           |             |
|--|-------|-------|-------------|-----------|-------------|
| Sampling Plane Validation Criteria             | Value | Units | Requirement | Compliant | Method      |
| Lowest Differential Pressure                   | 275   | Pa    | >= 5 Pa     | Yes       | BS EN 15259 |
| Lowest Gas Velocity                            | 18.8  | m/s   | -           | -         | -           |
| Highest Gas Velocity                           | 20.1  | m/s   | -           | -         | -           |
| Ratio of Gas Velocities                        | 1.1   | : 1   | < 3 : 1     | Yes       | BS EN 15259 |
| Mean Velocity                                  | 19.3  | m/s   | -           | -         | -           |
| Maximum angle of flow with regard to duct axis | <15   | °     | < 15°       | Yes       | BS EN 15259 |
| No local negative flow                         | Yes   | -     | -           | Yes       | BS EN 15259 |

| DUCT CHARACTERISTICS |          |                |
|----------------------|----------|----------------|
|                      | Value    | Units          |
| Shape                | Circular | -              |
| Depth                | 0.60     | m              |
| Width                | -        | m              |
| Area                 | 0.28     | m <sup>2</sup> |
| Port Depth           | 90       | mm             |

| SAMPLING LINES & POINTS |               |                 |
|-------------------------|---------------|-----------------|
|                         | Isokinetic    | Non-Iso & Gases |
| Sample port size        | 3.75 inch BSP | -               |
| Number of lines used    | 1             | -               |
| Number of points / line | 4             | -               |
| Duct orientation        | Vertical      | -               |
| Filtration for TPM      | In Stack      | -               |

| SAMPLING PLATFORM  |           |
|--|-----------|
| General Platform Information                                       |           |
| Permanent / Temporary Platform / Ground level / Floor Level / Roof | Permanent |
| Inside / Outside   | Outside   |

| M1 Platform requirements  |     |
|---|-----|
| Is there a sufficient working area so work can be performed in a compliant manner | Yes |
| Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)             | Yes |
| Platform has vertical base boards (approximately 0.25 m high)                     | Yes |
| Platform has removable chains / self closing gates at the top of ladders          | Yes |
| Handrail / obstructions do not hamper insertion of sampling equipment             | Yes |
| Depth of Platform = >Stack depth / diameter + wall and port thickness + 1.5m      | Yes |

### Sampling Platform Improvement Recommendations (if applicable)

The sampling location meets all the requirements as specified in EA Guidance Note M1.

## EXECUTIVE SUMMARY

### Sampling & Analytical Method Deviations

#### **CEMEX Deviation**

Due to limited production on the day of the emissions monitoring, sampling was only possible over 2 sampling periods as opposed to the 3 sampling runs the process guidance note outlines as an ideal. BS EN 13284-1 stipulates a minimum sampling duration of 30mins, in order to obtain a compliant result this minimum duration for sampling has been met, the overall effect of not obtaining a third sample (or second, change as appropriate) is seen as negligible and the result fully compliant.

#### **Sample Points**

The sampling point requirements of EN 13284-1 could not be met as one of the sample ports is siezed. As required in MID 13284-1 for such situations the number of sampling points has been doubled.

#### **Nozzle Size**

Due to the high stack velocity a nozzle less than 6mm was used.

APPENDICES

**CONTENTS**

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

| MONITORING SCHEDULE |   |                                      |                    |                                |                      |
|---------------------|---|--------------------------------------|--------------------|--------------------------------|----------------------|
| Species             | Method<br>Standard Reference Method /<br>Alternative Method | SOCOTEC UK<br>Technical<br>Procedure | UKAS Lab<br>Number | MCERTS<br>Accredited<br>Method | Number of<br>Samples |
| TPM                 | SRM - BS EN 13284-1   | AE 104                               | 1015               | Yes                            | 2                    |
| H <sub>2</sub> O    | SRM - BS EN 14790   | AE 105                               | 1015               | Yes                            | 1                    |
| Velocity            | SRM - BS EN ISO 16911-1                                     | AE 154                               | 1015               | Yes                            | 1                    |

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

| CALIBRATEABLE EQUIPMENT CHECKLIST |                |                                 |                |                           |                |
|-----------------------------------|----------------|---------------------------------|----------------|---------------------------|----------------|
| Extractive Sampling               |                | Instrumental Analyser/s         |                | Miscellaneous             |                |
| Equipment                         | Equipment I.D. | Equipment                       | Equipment I.D. | Equipment                 | Equipment I.D. |
| Control Box DGM                   | LNO 13-17      | Horiba PG-250 Analyser          | -              | Laboratory Balance        | LNO 0013/0014  |
| Box Thermocouples                 | LNO 03-17      | FT-IR Gasmet                    | -              | Tape Measure              | LNO 18-AH      |
| Meter In Thermocouple             | LNO 03-17      | FT-IR Oven Box                  | -              | Stopwatch                 | LNO 17-AH      |
| Meter Out Thermocouple            | LNO 03-17      | Bernath 3006 FID                | -              | Protractor                | -              |
| Control Box Timer                 | LNO 03-17      | Signal 3030 FID                 | -              | Barometer                 | LNO 08-AH      |
| Oven Box                          | -              | Servomex                        | -              | Digital Micromanometer    | -              |
| Probe                             | LNO 11-08      | JCT Heated Head Filter          | -              | Digital Temperature Meter | -              |
| Probe Thermocouple                | LNO 10-08      | Thermo FID                      | -              | Stack Thermocouple        | -              |
| Probe                             | -              | Stackmaster                     | -              | Mass Flow Controller      | -              |
| Probe Thermocouple                | -              | FTIR Heater Box for Heated Line | -              | MFC Display module        | -              |
| S-Pitot                           | LNO 06-AH      | Anemometer                      | -              | 1m Heated Line (1)        | -              |
| L-Pitot                           | -              | Ecophysics NOx Analyser         | -              | 1m Heated Line (2)        | -              |
| Site Balance                      | LNO 14-AH      | Chiller (JCT/MAK 10)            | -              | 1m Heated Line (3)        | -              |
| Last Impinger Arm                 | -              | Heated Line Controller (1)      | -              | 5m Heated Line (1)        | -              |
| Dioxins Cond. Thermocouple        | -              | Heated Line Controller (2)      | -              | 10m Heated Line (1)       | -              |
| Callipers                         | LNO 31-AH      | Site temperature Logger         | -              | 10m Heated Line (2)       | -              |
| Small DGM                         | -              |                                 | -              | 15m Heated Line (1)       | -              |
| Heater Controller                 | -              |                                 | -              | 20m Heated Line (1)       | -              |
| Inclinometer (Swirl Device)       | LNO 23-AH      |                                 | -              | 20m Heated Line (2)       | -              |

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

| CALIBRATION GASES            |                     |          |     |   |                            |
|------------------------------|---------------------|----------|-----|---|----------------------------|
| Gas (traceable to ISO 17025) | Cylinder I.D Number | Supplier | ppm | % | Analytical Tolerance +/- % |
| -                            | -                   | -        | -   | - | -                          |

**STACK EMISSIONS MONITORING TEAM**

| MONITORING TEAM |               |                |        |   |        |        |        |        |
|-----------------|---------------|----------------|--------|---|--------|--------|--------|--------|
| Personnel       | MCERTS Number | MCERTS         |        | TE / H&S Qualifications and Expiry Date |        |        |        |        |
|                 |               | Level          | Expiry | TE1                                     | TE2    | TE3    | TE4    | H&S    |
| Andy Hegarty    | MM 03 397     | MCERTS Level 2 | Jan-19 | Oct-19                                  | Dec-20 | Aug-21 | Dec-19 | Jan-19 |
| Lindsay Adams   | MM 14 1275    | MCERTS Level 2 | May-21 | May-20                                  | Jul-20 | Nov-20 | Feb-21 | Mar-19 |

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

| TOTAL PARTICULATE MATTER SUMMARY |                                  |                                    |                                  |                            |                       |
|----------------------------------|----------------------------------|------------------------------------|----------------------------------|----------------------------|-----------------------|
| Parameter                        | Sampling Times                   | Concentration<br>mg/m <sup>3</sup> | Uncertainty<br>mg/m <sup>3</sup> | Limit<br>mg/m <sup>3</sup> | Emission<br>Rate g/hr |
| Run 1                            | 08:29 - 09:01<br>19 October 2018 | 29                                 | 1.2                              | 50                         | 447                   |
| Run 2                            | 09:15 - 09:47<br>19 October 2018 | 31                                 | 1.2                              | 50                         | 479                   |
| Blank                            | -                                | 3.7                                | -                                | -                          | -                     |

Reference conditions are 273K, 101.3kPa without correction for water vapour

| Acetone Blank Value<br>mg/l | Acceptable Value<br>mg/l |
|-----------------------------|--------------------------|
| 2.0                         | 10                       |

**FILTER INFORMATION**

| SAMPLES |                                |                             |                           |                               |                                  |                                |                              |                                       |
|---------|--------------------------------|-----------------------------|---------------------------|-------------------------------|----------------------------------|--------------------------------|------------------------------|---------------------------------------|
| Test    | Filter & Probe<br>Rinse Number | Filter Start<br>Weight<br>g | Filter End<br>Weight<br>g | Mass Gained<br>on Filter<br>g | Probe Rinse<br>Start Weight<br>g | Probe Rinse<br>End Weight<br>g | Mass Gained<br>on Probe<br>g | Combined<br>Total Mass<br>Gained<br>g |
| Run 1   | G8960                          | 0.10735                     | 0.11722                   | 0.00987                       | 190.84590                        | 190.85120                      | 0.00530                      | 0.01517                               |
| Run 2   | G8961                          | 0.10702                     | 0.11900                   | 0.01198                       | 199.98130                        | 199.98580                      | 0.00450                      | 0.01648                               |

If total mass gained is less than the LOD then the LOD is reported

| BLANKS |                          |                             |                           |                            |                            |                          |                           |                                       |
|--------|--------------------------|-----------------------------|---------------------------|----------------------------|----------------------------|--------------------------|---------------------------|---------------------------------------|
| Test   | Filter & Probe<br>Number | Filter Start<br>Weight<br>g | Filter End<br>Weight<br>g | Mass Gained<br>Filter<br>g | Probe Start<br>Weight<br>g | Probe End<br>Weight<br>g | Mass Gained<br>Probe<br>g | Combined<br>Total Mass<br>Gained<br>g |
| Run 1  | G8991                    | 0.10649                     | 0.10647                   | -0.00002                   | 168.35700                  | 168.35900                | 0.00200                   | 0.00198                               |

If total mass gained is less than the LOD then the LOD is reported

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

| ISOKINETIC SAMPLING EQUATIONS - RUN 1  |  |                       | TPM  |                     |                       |
|--|--|-----------------------|--|---------------------|-----------------------|
| <b>Absolute pressure of stack gas, P<sub>s</sub></b>                                     |  |                       | <b>Molecular weight of dry gas, M<sub>d</sub></b>                              |                     |                       |
| Barometric pressure, P <sub>b</sub>  | mm Hg  | 769.51                | CO <sub>2</sub>  | %                   | 0.08                  |
| Stack static pressure, P <sub>static</sub>   | mm H <sub>2</sub> O                            | 6.12                  | O <sub>2</sub>   | %                   | 20.90                 |
| $P_s = \frac{P_b + (P_{static})}{13.6}$  | mm Hg  | 769.96                | Total  | %                   | 20.98                 |
| <b>Vol. of water vapour collected, V<sub>wstd</sub></b>                                  |  |                       | N <sub>2</sub> (100 - Total)   | %                   | 79.02                 |
| Moisture trap weight increase, Vlc   | g  | 11.0                  | $M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$                               |                     | 28.85                 |
| $V_{wstd} = (0.001246)(V_{lc})$  | m <sup>3</sup>                                 | 0.013706              | <b>Molecular weight of wet gas, M<sub>s</sub></b>                              |                     |                       |
| <b>Volume of gas metered dry, V<sub>mstd</sub></b>                                       |  |                       | $M_s = M_d(1 - B_{wo}) + 18(B_{wo})$   | g/gmol              | 28.57                 |
| Volume of gas sample through gas meter, V <sub>m</sub>                                   |  | 0.534                 | <b>Actual flow of stack gas, Q<sub>a</sub></b>                                 |                     |                       |
| Gas meter correction factor, Y <sub>d</sub>  |  | 0.981                 | Area of stack, A <sub>s</sub>  | m <sup>2</sup>      | 0.28                  |
| Mean dry gas meter temperature, T <sub>m</sub>   | °  | 10.500                | $Q_a = (60)(A_s)(V_s)$   | m <sup>3</sup> /min | 331.3                 |
| Mean pressure drop across orifice, DH  | mmH <sub>2</sub> O                             | 36.558                | <b>Total flow of stack gas, Q</b>  |                     |                       |
| $V_{mstd} = \frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$                       | m <sup>3</sup>                                 | 0.513                 | Conversion factor (K/mm.Hg)  |                     | 0.3592                |
| <b>Volume of gas metered wet, V<sub>mstw</sub></b>                                       |  |                       | $Q_{std} = \frac{(Q_a)P_s(0.3592)(1 - B_{wo})}{(T_s) + 273}$                   | Dry                 | 251.9                 |
| $V_{mstw} = V_{mstd} + V_{wstd}$   | m <sup>3</sup>                                 | 0.5262                | $Q_{stdO_2} = \frac{(Q_a)P_s(0.3592)(1 - B_{wo})(O_2REF)}{(T_s) + 273}$        | @O <sub>2</sub> ref | No O <sub>2</sub> Ref |
| <b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b> |  |                       | $Q_{stw} = \frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$                               | Wet                 | 258.59                |
| Is the process burning hazardous waste? (If yes, no favourable oxygen correction)        |  | No                    | <b>Percent isokinetic, %I</b>  |                     |                       |
| % oxygen measured in gas stream, act%O <sub>2</sub>                                      |  | 20.9                  | Nozzle diameter, D <sub>n</sub>  | mm                  | 4.88                  |
| % oxygen reference condition   |  | 21                    | Nozzle area, A <sub>n</sub>  | mm <sup>2</sup>     | 18.73                 |
| O <sub>2</sub> Reference   | O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub> | No O <sub>2</sub> Ref | Total sampling time, q   | min                 | 32                    |
| Factor   | $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$      | No O <sub>2</sub> Ref | $\%I = \frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1 - B_{wo})}$ | %                   | 96.0                  |
| $V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$   | m <sup>3</sup>                                 | No O <sub>2</sub> Ref | Acceptable isokinetic range 95% to 115%  |                     | Yes                   |
| <b>Moisture content, B<sub>wo</sub></b>  |  |                       | <b>Particulate Concentration, C</b>  |                     |                       |
| $B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$  | %  | 0.0260                | Mass collected on filter, M <sub>f</sub>                                       | g                   | 0.00987               |
| <b>Moisture by FTIR</b>  |  |                       | Mass collected in probe, M <sub>p</sub>  | g                   | 0.00530               |
|  | %  | -                     | Total mass collected, M <sub>n</sub>   | g                   | 0.01517               |
| <b>Velocity of stack gas, V<sub>s</sub></b>  |  |                       | $C_{wet} = \frac{M_n}{V_{mstw}}$   | mg/m <sup>3</sup>   | 28.827                |
| Pitot tube velocity constant, K <sub>p</sub>   |  | 34.97                 | $C_{dry} = \frac{M_n}{V_{mstd}}$   | mg/m <sup>3</sup>   | 29.598                |
| Velocity pressure coefficient, C <sub>p</sub>  |  | 0.81                  | $C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$                              | mg/m <sup>3</sup>   | No O <sub>2</sub> Ref |
| Mean of velocity heads, DP <sub>avg</sub>  | mm H <sub>2</sub> O                            | 29.50                 | <b>Particulate Emission Rates, E</b>   |                     |                       |
| Mean square root of velocity heads, ÖDP  |  | 5.43                  | $E = [(C_{wet})(Q_{stw})(60)] / 1000$  |                     | 447.26                |
| Mean stack gas temperature, T <sub>s</sub>   | °C   | 81                    |  |                     |                       |
| $V_s = \frac{(K_p)(C_p)(\ddot{O}DP)(\ddot{O}(T_s + 273))}{(M_s)(P_s)}$                   | m/s  | 19.53                 |  |                     |                       |

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

| ISOKINETIC SAMPLING EQUATIONS - RUN 2   |  |           | TPM |
|---|--|-----------|-----|
| <b>Absolute pressure of stack gas, P<sub>s</sub></b>                              |  |           |     |
| Barometric pressure, P <sub>b</sub>   | mm Hg  | 769.51    |     |
| Stack static pressure, P <sub>static</sub>  | mm H <sub>2</sub> O                            | 6.12      |     |
| $P_s = \frac{P_b + (P_{static})}{13.6}$   | mm Hg  | 769.96    |     |
| <b>Vol. of water vapour collected, V<sub>wstd</sub></b>                           |  |           |     |
| Moisture trap weight increase, V <sub>lc</sub>                                    | g  | -         |     |
| $V_{wstd} = (0.001246)(V_{lc})$   | m <sup>3</sup>                                 | -         |     |
| <b>Volume of gas metered dry, V<sub>mstd</sub></b>                                |  |           |     |
| Volume of gas sample through gas meter, V <sub>m</sub>                            |  | 0.550     |     |
| Gas meter correction factor, Y <sub>d</sub>                                       |  | 0.981     |     |
| Mean dry gas meter temperature, T <sub>m</sub>                                    |  | 12.500    |     |
| Mean pressure drop across orifice, DH   | mmH <sub>2</sub> O                             | 37.452    |     |
| $V_{mstd} = \frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$                | m <sup>3</sup>                                 | 0.524     |     |
| <b>Volume of gas metered wet, V<sub>mstw</sub></b>                                |  |           |     |
| $V_{mstw} = V_{mstd} + V_{wstd}$  | m <sup>3</sup>                                 | 0.5383    |     |
| <b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>     |  |           |     |
| Is the process burning hazardous waste? (If yes, no favourable oxygen correction) |  | No        |     |
| % oxygen measured in gas stream, act%O <sub>2</sub>                               |  | 20.9      |     |
| % oxygen reference condition  |  | 21        |     |
| O <sub>2</sub> Reference  | O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub> | No O2 Ref |     |
| Factor  | $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$      |           |     |
| $V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$                                       | m <sup>3</sup>                                 | No O2 Ref |     |
| <b>Moisture content, B<sub>w0</sub></b>   |  |           |     |
| $B_{w0} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$                                   | %  | 0.0260    |     |
|   |  | 2.60      |     |
| <b>Moisture by FTIR</b>   |  |           |     |
|   | %  | -         |     |
| <b>Velocity of stack gas, V<sub>s</sub></b>                                       |  |           |     |
| Pitot tube velocity constant, K <sub>p</sub>                                      |  | 34.97     |     |
| Velocity pressure coefficient, C <sub>p</sub>                                     |  | 0.81      |     |
| Mean of velocity heads, DP <sub>avg</sub>   | mm H <sub>2</sub> O                            | 30.00     |     |
| Mean square root of velocity heads, ÖDP   |  | 5.48      |     |
| Mean stack gas temperature, T <sub>s</sub>  | °C   | 81        |     |
| $V_s = \frac{(K_p)(C_p)(\sqrt{DP})(\sqrt{T_s + 273})}{(M_s)(P_s)}$                | m/s  | 19.69     |     |
| <b>Molecular weight of dry gas, M<sub>d</sub></b>                                 |  |           |     |
| CO <sub>2</sub>   | %  | 0.08      |     |
| O <sub>2</sub>  | %  | 20.90     |     |
| Total   | %  | 20.98     |     |
| N <sub>2</sub> (100 - Total)  | %  | 79.02     |     |
| $M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$                                  |  | 28.85     |     |
| <b>Molecular weight of wet gas, M<sub>s</sub></b>                                 |  |           |     |
| $M_s = M_d(1 - B_{w0}) + 18(B_{w0})$  | g/gmol   | 28.57     |     |
| <b>Actual flow of stack gas, Q<sub>a</sub></b>                                    |  |           |     |
| Area of stack, A <sub>s</sub>   | m <sup>2</sup>                                 | 0.28      |     |
| $Q_a = (60)(A_s)(V_s)$  | m <sup>3</sup> /min                            | 334.1     |     |
| <b>Total flow of stack gas, Q</b>   |  |           |     |
| Conversion factor (K/mm.Hg)   |  | 0.3592    |     |
| $Q_{std} = \frac{(Q_a)P_s(0.3592)(1 - B_{w0})}{(T_s) + 273}$                      | Dry  | 254.0     |     |
| $Q_{stdO_2} = \frac{(Q_a)P_s(0.3592)(1 - B_{w0})(O_2REF)}{(T_s) + 273}$           | @O <sub>2</sub> ref                            | No O2 Ref |     |
| $Q_{stw} = \frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$                                  | Wet  | 260.82    |     |
| <b>Percent isokinetic, %I</b>   |  |           |     |
| Nozzle diameter, D <sub>n</sub>   | mm   | 4.88      |     |
| Nozzle area, A <sub>n</sub>   | mm <sup>2</sup>                                | 18.73     |     |
| Total sampling time, q  | min  | 32        |     |
| $\%I = \frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1 - B_{w0})}$    | %  | 97.4      |     |
| Acceptable isokinetic range 95% to 115%   |  | Yes       |     |
| <b>Particulate Concentration, C</b>   |  |           |     |
| Mass collected on filter, M <sub>f</sub>  | g  | 0.01198   |     |
| Mass collected in probe, M <sub>p</sub>   | g  | 0.00450   |     |
| Total mass collected, M <sub>n</sub>  | g  | 0.01648   |     |
| $C_{wet} = \frac{M_n}{V_{mstw}}$  | mg/m <sup>3</sup>                              | 30.62     |     |
| $C_{dry} = \frac{M_n}{V_{mstd}}$  | mg/m <sup>3</sup>                              | 31.44     |     |
| $C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$                                 | mg/m <sup>3</sup>                              | No O2 Ref |     |
| <b>Particulate Emission Rates, E</b>  |  |           |     |
| $E = [(C_{wet})(Q_{stw})(60)] / 1000$   |  | 479.13    |     |



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**TOTAL PARTICULATE MATTER QUALITY ASSURANCE CHECKLIST**

| LEAK RATE |                                 |                                     |                                      |                         |                                   |                        |
|-----------|---------------------------------|-------------------------------------|--------------------------------------|-------------------------|-----------------------------------|------------------------|
| Run       | Mean Sampling Rate<br>litre/min | Pre-sampling Leak Rate<br>litre/min | Post-sampling Leak Rate<br>litre/min | Maximum Vacuum<br>mm Hg | Acceptable Leak Rate<br>litre/min | Leak Tests Acceptable? |
| Run 1     | 16.37                           | 0.00                                | 0.10                                 | -228.6                  | 0.33                              | Yes                    |
| Run 2     | 16.86                           | 0.10                                | 0.00                                 | -254                    | 0.34                              | Yes                    |

| ISOKINETICITY |                           |                          |
|---------------|---------------------------|--------------------------|
| Run           | Isokinetic Variation<br>% | Acceptable Isokineticity |
| Run 1         | 96.00                     | Yes                      |
| Run 2         | 97.36                     | Yes                      |

Acceptable isokinetic range 95% to 115%

| WEIGHING BALANCE UNCERTAINTY |                             |                             |              |
|------------------------------|-----------------------------|-----------------------------|--------------|
| Run                          | Result<br>mg/m <sup>3</sup> | 5% ELV<br>mg/m <sup>3</sup> | LOD < 5% ELV |
| Run 1                        | 0.46                        | 2.5                         | Yes          |
| Run 2                        | 0.45                        | 2.5                         | Yes          |

The above is based on both the Filter and rinse uncertainty

| BLANK VALUE |  |   |   |   |
|-------------|--|---|---|---|
| Run         | Overall Blank Value<br>mg/m <sup>3</sup> | Daily Emission Limit Value<br>mg/m <sup>3</sup> | Acceptable Blank Value<br>mg/m <sup>3</sup> | Overall Blank Acceptable<br>mg/m <sup>3</sup> |
| Blank 1     | 3.74                                     | 50  | 5.0   | Yes   |

| FILTERS |                 |                   |                                  |   |  |
|---------|-----------------|-------------------|----------------------------------|---|--|
| Run     | Filter Material | Filter Size<br>mm | Max Filtration Temperature<br>°C | Pre-use Filter Conditioning Temperature<br>°C | Post-use Filter Conditioning Temperature<br>°C |
| Run 1   | Glass Fibre     | 47                | 83                               | 180   | 160  |
| Run 2   | Glass Fibre     | 47                | 83                               | 180   | 160  |

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**MOISTURE CALCULATIONS**

| Moisture Determination - Isokinetic |                                  |              |            |            |               |      |             |
|-------------------------------------|----------------------------------|--------------|------------|------------|---------------|------|-------------|
| Test Number                         | Sampling Time and Date           | Start Weight | End Weight | Total gain | Concentration | LOD  | Uncertainty |
|                                     |                                  | kg           | kg         | kg         | %             | %    | %           |
| Run 1                               | 08:29 - 09:01<br>19 October 2018 | 3.5460       | 3.5570     | 0.0110     | 2.6           | 0.02 | 3.4         |

| Moisture Quality Assurance |                   |                      |               |                 |               |                      |                        |
|----------------------------|-------------------|----------------------|---------------|-----------------|---------------|----------------------|------------------------|
| Test Number                | Sampling Duration | Total Volume Sampled | Sampling Rate | Start Leak Rate | End Leak Rate | Acceptable Leak Rate | Leak Tests Acceptable? |
|                            | mins              | l                    | l/min         | l/min           | l/min         | l/min                |                        |
| Run 1                      | 32                | 526                  | 16.4          | 0.00            | 0.10          | 0.33                 | Yes                    |

**PRELIMINARY STACK SURVEY**

| Stack Characteristics         |       |                |
|-------------------------------|-------|----------------|
| Stack Diameter / Depth, D     | 0.60  | m              |
| Stack Width, W                | -     | m              |
| Stack Area, A                 | 0.28  | m <sup>2</sup> |
| Average stack gas temperature | 78    | °C             |
| Stack static pressure         | 0.06  | kPa            |
| Barometric Pressure           | 102.6 | kPa            |

| Stack Gas Composition & Molecular Weights |              |                             |                |                       |                               |                |                       |                               |
|---|--------------|-----------------------------|----------------|-----------------------|-------------------------------|----------------|-----------------------|-------------------------------|
| Component                                 | Molar Mass M | Density kg/m <sup>3</sup> p | Conc Dry % Vol | Dry Volume Fraction r | Dry Conc kg/m <sup>3</sup> pi | Conc Wet % Vol | Wet Volume Fraction r | Wet Conc kg/m <sup>3</sup> pi |
| CO <sub>2</sub>                           | 44           | 1.963059                    | 0.075238       | 0.000752              | 0.001477                      | 0.073279       | 0.000733              | 0.001439                      |
| O <sub>2</sub>                            | 32           | 1.427679                    | 20.900000      | 0.209000              | 0.298385                      | 20.355654      | 0.203557              | 0.290613                      |
| N <sub>2</sub>                            | 28           | 1.249219                    | 79.024762      | 0.790248              | 0.987193                      | 76.966542      | 0.769665              | 0.961481                      |
| H <sub>2</sub> O                          | 18           | 0.803070                    | -              | -                     | -                             | 2.604525       | 0.026045              | 0.020916                      |

Where:  $p = M / 22.41$      $pi = r \times p$

| Calculation of Stack Gas Densities          |        |                   |
|---|--------|-------------------|
| Determinand                                 | Result | Units             |
| Dry Density (STP), $P_{STD}$                | 1.2871 | kg/m <sup>3</sup> |
| Wet Density (STP), $P_{STW}$                | 1.2744 | kg/m <sup>3</sup> |
| Dry Density (Actual), $P_{Actual}$          | 1.0159 | kg/m <sup>3</sup> |
| Average Wet Density (Actual), $P_{ActualW}$ | 1.006  | kg/m <sup>3</sup> |

Where:

$P_{STD}$  = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)

$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$

$P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$

$P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

|                              |                 |
|------------------------------|-----------------|
| Date of Survey               | 19 October 2018 |
| Time of Survey               | 08:12           |
| Velocity Measurement Device: | S-Type Pitot    |

| Sampling Line A |                        |  |                                  |         |              |   |                      |                  |
|-----------------|------------------------|--|----------------------------------|---------|--------------|---|----------------------|------------------|
| Traverse Point  | Distance into duct (m) | DP pt mmH <sub>2</sub> O (average of 3 readings) | DP pt Pa (average of 3 readings) | Temp °C | Velocity m/s | Volumetric Flow Rate (actual) m <sup>3</sup> /s | O <sub>2</sub> % Vol | Angle of Swirl ° |
| 1               | 0.05                   | 28.0   | 274                              | 77      | 18.8         | 5.3   | -                    | <15              |
| 2               | 0.15                   | 32.0   | 314                              | 77      | 20.1         | 5.7   | -                    | <15              |
| 3               | 0.45                   | 30.0   | 294                              | 78      | 19.5         | 5.5   | -                    | <15              |
| 4               | 0.55                   | 28.0   | 274                              | 78      | 18.8         | 5.3   | -                    | <15              |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| Mean            | -                      | 29.5   | 289                              | 78      | 19.3         | 5.5   | -                    | -                |

| Sampling Line B |                        |  |                                  |         |              |   |                      |                  |
|-----------------|------------------------|--|----------------------------------|---------|--------------|---|----------------------|------------------|
| Traverse Point  | Distance into duct (m) | DP pt mmH <sub>2</sub> O (average of 3 readings) | DP pt Pa (average of 3 readings) | Temp °C | Velocity m/s | Volumetric Flow Rate (actual) m <sup>3</sup> /s | O <sub>2</sub> % Vol | Angle of Swirl ° |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| -               | -                      | -  | -                                | -       | -            | -   | -                    | -                |
| Mean            | -                      | -  | -                                | -       | -            | -   | -                    | -                |

**PRELIMINARY STACK SURVEY QUALITY ASSURANCE CHECKLIST**

| PITOT LEAK CHECK |                        |              |              |         |                         |              |              |         |
|------------------|------------------------|--------------|--------------|---------|-------------------------|--------------|--------------|---------|
| Run              | Pre Traverse Leak Rate |              |              |         | Post Traverse Leak Rate |              |              |         |
|                  | Start Value Pa         | End Value Pa | Difference % | Outcome | Start Value Pa          | End Value Pa | Difference % | Outcome |
| Run 1            | 96                     | 96           | 0.0          | Pass    | 102                     | 102          | 0.0          | Pass    |

To complete a compliant pitot leak check a pressure of over 80 mmH<sub>2</sub>O (or 800 Pa) is applied and the pressure drop monitored over 5 mins. A drop of less than 5% must be observed.

| S-Type Pitot Stagnation Check |                 |                |                 |                               |
|-------------------------------|-----------------|----------------|-----------------|-------------------------------|
| Run                           | Stagnation (Pa) | Reference (Pa) | Difference (Pa) | Outcome (Permitted +/- 10 Pa) |
| Run 1                         | 60              | 60             | 0.0             | Pass                          |

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

| Sampling Plane Validation Criteria             |        |       |             |           |
|--|--------|-------|-------------|-----------|
| EA Technical Guidance Note (Monitoring) M1     | Result | Units | Requirement | Compliant |
| Lowest Differential Pressure                   | 274    | Pa    | >= 5 Pa     | Yes       |
| Lowest Gas Velocity                            | 18.8   | m/s   | -           | -         |
| Highest Gas Velocity                           | 20.1   | m/s   | -           | -         |
| Ratio of Gas Velocities                        | 1.1    | -     | < 3 : 1     | Yes       |
| Maximum angle of flow with regard to duct axis | <15    | °     | < 15°       | Yes       |
| No local negative flow                         | Yes    | -     | -           | Yes       |

| Calculation of Stack Gas Velocity, V  |      |     |
|---|------|-----|
| Velocity at Traverse Point, $V = K_{pt} \times (1-e) \times \sqrt{2 * DP_{pt} / P_{ActualW}}$ |      |     |
| <b>Where:</b>   |      |     |
| $K_{pt}$ = Pitot tube calibration coefficient   |      |     |
| (1-e) = Compressibility correction factor, assumed at a constant 0.998                        |      |     |
| Average Stack Gas Velocity, $V_a$   | 19.3 | m/s |

| Calculation of Stack Gas Volumetric Flowrate, Q |        |           |       |
|---|--------|-----------|-------|
| Duct gas flow conditions                        | Actual | Reference | Units |
| Temperature                                     | 78     | 0         | °C    |
| Total Pressure                                  | 102.66 | 101.3     | kPa   |
| Oxygen  | 20.9   | 21        | %     |
| Moisture  | 2.60   | 2.60      | %     |
| Pitot tube calibration coefficient, $K_{pt}$    | 0.81   |           |       |

| Gas Volumetric Flowrate                           | Result | Units              |
|---|--------|--------------------|
| Average Stack Gas Velocity ( $V_a$ )              | 19.32  | m/s                |
| Stack Area (A)                                    | 0.28   | m <sup>2</sup>     |
| Gas Volumetric Flowrate (Actual), $Q_{Actual}$    | 19667  | m <sup>3</sup> /hr |
| Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$     | 15524  | m <sup>3</sup> /hr |
| Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$ | 15120  | m <sup>3</sup> /hr |
| Gas Volumetric Flowrate (REF), $Q_{Ref}$          | 15524  | m <sup>3</sup> /hr |

**Where:**

$$Q_{Actual} = V_a \times A \times 3600$$

$$Q_{STP} = Q_{Actual} \times (T_s / T_a) \times (P_a / P_s) \times 3600$$

$$Q_{STP,Dry} = Q_{STP} / (100 - (100 / Ma)) \times 3600$$

$$Q_{Ref} = Q_{STP} \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$$

**Nomenclature:**

$T_s$  = Absolute Temperature, Standard Conditions, 273 K

$P_s$  = Absolute Pressure, Standard Conditions, 101.3 kPa

$T_a$  = Absolute Temperature, Actual Conditions, K

$P_a$  = Absolute Pressure, Actual Conditions, kPa

$Ma$  = Water vapour, Actual Conditions, % Vol

$Ms$  = Water vapour, Reference Conditions, % Vol

$O_{2a}$  = Oxygen, Actual Conditions, % Vol

$O_{2s}$  = Oxygen, Reference Conditions, % Vol


APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

|             | Value | Units          |
|-------------|-------|----------------|
| Stack Depth | 0.60  | m              |
| Stack Width | -     | m              |
| Area        | 0.28  | m <sup>2</sup> |

| Non-Isokinetic/Gases Sampling |                       |                     |       |
|-------------------------------|-----------------------|---------------------|-------|
| Sampling Point                | Distance (% of Depth) | Distance into Stack | Units |
| -                             | -                     | -                   | -     |

| Isokinetic Sampling |                       |                         |         |
|---------------------|-----------------------|-------------------------|---------|
| Sampling Point      | Distance (% of Depth) | Distance into Stack (m) | Swirl ° |
| 1                   | 8.3                   | 0.05                    | < 15    |
| 2                   | 25.0                  | 0.15                    | < 15    |
| 3                   | 75.0                  | 0.45                    | < 15    |
| 4                   | 91.7                  | 0.55                    | < 15    |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |
| -                   | -                     | -                       | -       |



- Isokinetic sampling point
- Isokinetic sampling points not used
- Non Isokinetic/Gases sampling point

**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - TOTAL PARTICULATE MATTER**

| Run                | Sampled Volume<br>m <sup>3</sup> | Sampled Gas Temp<br>K | Sampled Gas Pressure<br>kPa | Sampled Gas Humidity<br>% by volume | Oxygen Content<br>% by volume | Limit of Detection<br>% by mass | Leak<br>%   | Uncollected Mass<br>mg |
|--------------------|----------------------------------|-----------------------|-----------------------------|-------------------------------------|-------------------------------|---------------------------------|-------------|------------------------|
| <b>MU required</b> | <b>≤ 2%</b>                      | <b>≤ 2%</b>           | <b>≤ 1%</b>                 | <b>≤ 1%</b>                         | <b>≤ 10%</b>                  | <b>≤ 5% of ELV</b>              | <b>≤ 2%</b> | <b>≤ 10% of ELV</b>    |
| Run 1              | 0.001                            | 2.0                   | 0.50                        | 1.0                                 | N/A                           | 0.2400                          | -           | -                      |
| as a %             | 0.20                             | 0.56                  | 0.49                        | 1.0                                 | N/A                           | 0.91213                         | 0.61        | 0.004                  |
| <b>compliant?</b>  | <b>Yes</b>                       | <b>Yes</b>            | <b>Yes</b>                  | <b>Yes</b>                          | <b>N/A</b>                    | <b>Yes</b>                      | <b>Yes</b>  | <b>Yes</b>             |
| Run 2              | 0.0011                           | 2.0                   | 0.50                        | 1.0                                 | N/A                           | 0.240                           | -           | -                      |
| as a %             | 0.20                             | 0.70                  | 0.49                        | 1.0                                 | N/A                           | 0.892                           | 0.00000     | 0.004                  |
| <b>compliant?</b>  | <b>Yes</b>                       | <b>Yes</b>            | <b>Yes</b>                  | <b>Yes</b>                          | <b>N/A</b>                    | <b>Yes</b>                      | <b>Yes</b>  | <b>Yes</b>             |

| Run                     | Volume (STP)<br>m <sup>3</sup> | Mass of particulate<br>mg | O <sub>2</sub> Correction<br>- | Leak<br>mg/m <sup>3</sup> | Uncollected Mass<br>mg | Combined uncertainty |
|-------------------------|--------------------------------|---------------------------|--------------------------------|---------------------------|------------------------|----------------------|
| Run 1                   | 0.40                           | 15.1700                   | 1.0                            | 0.102                     | 0.0011                 | -                    |
| MU as mg/m <sup>3</sup> | 0.37                           | 0.4561                    | -                              | 0.102                     | 0.0022                 | <b>0.59</b>          |
| MU as %                 | 1.27                           | 1.5821                    | -                              | 0.353                     | 0.0075                 | -                    |
| Run 2                   | 0.52                           | 16.4800                   | 1.0                            | 0.000                     | 0.0011                 | -                    |
| MU as mg/m <sup>3</sup> | 0.41                           | 0.4459                    | -                              | 0.00000                   | 0.0021                 | <b>0.60</b>          |
| MU as %                 | 1.3                            | 1.4563                    | -                              | 0.00000                   | 0.0069                 | -                    |

|   |             |                         |             |          |
|---|-------------|-------------------------|-------------|----------|
| <b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b> | <b>1.19</b> | <b>mg/m<sup>3</sup></b> | <b>4.12</b> | <b>%</b> |
|---|-------------|-------------------------|-------------|----------|

|   |             |                         |             |          |
|---|-------------|-------------------------|-------------|----------|
| <b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b> | <b>1.21</b> | <b>mg/m<sup>3</sup></b> | <b>3.95</b> | <b>%</b> |
|---|-------------|-------------------------|-------------|----------|

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Reference – SOCOTEC UK Technical Procedure AE150 Estimation of Uncertainty of Measurement

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MOISTURE**

| Run                | Sampled Volume<br>m <sup>3</sup> | Sampled Gas Temp<br>K | Sampled Gas Pressure<br>kPa | Sampled Gas Humidity<br>% by volume | Oxygen Content<br>% by volume | Leak<br>%   |
|--------------------|----------------------------------|-----------------------|-----------------------------|-------------------------------------|-------------------------------|-------------|
| <b>MU required</b> | <b>≤ 2%</b>                      | <b>≤ 2%</b>           | <b>≤ 1%</b>                 | <b>≤ 1%</b>                         | <b>≤ 10%</b>                  | <b>≤ 2%</b> |
| Run 1              | 0.001                            | 2.0                   | 0.50                        | 1.0                                 | N/A                           | -           |
| as a %             | 0.20                             | 0.56                  | 0.49                        | 1.0                                 | N/A                           | 0.61        |
| <b>compliant?</b>  | <b>Yes</b>                       | <b>Yes</b>            | <b>Yes</b>                  | <b>Yes</b>                          | <b>N/A</b>                    | <b>Yes</b>  |

| Run         | Volume (STP)<br>m <sup>3</sup> | Mass Gained<br>mg | O <sub>2</sub> Correction<br>- | Leak<br>mg/m <sup>3</sup> | Uncollected Mass<br>mg | Combined uncertainty |
|-------------|--------------------------------|-------------------|--------------------------------|---------------------------|------------------------|----------------------|
| Run 1       | 0.40                           | 11000             | 1.0                            | 75.69                     | 58                     | -                    |
| MU as % v/v | 0.03                           | 0.02              | -                              | 0.01                      | 0.014                  | <b>0.05</b>          |
| MU as %     | 1.27                           | 0.91              | -                              | 0.35                      | 0.52                   | -                    |

|   |             |              |             |          |
|---|-------------|--------------|-------------|----------|
| <b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b> | <b>0.09</b> | <b>% v/v</b> | <b>3.37</b> | <b>%</b> |
|---|-------------|--------------|-------------|----------|

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - VELOCITY & VOLUMETRIC FLOW RATE**

|  |       |                    |
|--|-------|--------------------|
| Measured Velocity at Actual Conditions             | 19.3  | m/s                |
| Measured Volumetric Flow rate at Actual Conditions | 19667 | m <sup>3</sup> /hr |

| Performance Characteristics & Source of Value                 | Units      | Values  | Requirement                                | Compliant |
|---|------------|---------|--|-----------|
| <b>Uncertainty of Local Gas Velocity Determination</b>        |            |         |  |           |
| Uncertainty of pitot tube coefficient                         | -          | 0.010   |  |           |
| Uncertainty of mean local dynamic pressures                   | -          | 0.45    |  |           |
| Factor loading, function of the number of measurements.       | 3 readings | 0.591   | minimum 3                                  | Yes       |
| Range of measurement device                                   | pa         | 1000    |  |           |
| Resolution  | pa         | 1.00    |  |           |
| Calibration uncertainty                                       | pa         | 6.21    | <1% of Value or 20 Pa whichever is greater | Yes       |
| Drift   | % range    | 0.10    |  |           |
| Linearity   | % range    | 0.06    | <2% of value                               | Yes       |
| <b>Uncertainty of gas density determination</b>               |            |         |  |           |
| Uncertainty of molar mass determination                       | kg/mol     | 0.00003 |  |           |
| Uncertainty of temperature measurement                        | K          | 1.79    | <1% of value                               | Yes       |
| Uncertainty of absolute pressure in the duct                  | pa         | 524     |  |           |
| Uncertainty associated with the estimate of density           | -          | 0.007   |  |           |
| Uncertainty associated with the measurement of local velocity | -          | 0.0002  |  |           |
| Uncertainty associated with the measurement of mean velocity  | -          | 0.0002  |  |           |

| Measurement Uncertainty - Velocity                | m/s  |
|---|------|
| Combined uncertainty                              | 0.25 |
| Expanded uncertainty at a 95% Confidence Interval | 0.49 |

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

| Expanded Measurement Uncertainty of Velocity at a 95% Confidence Interval | %   |
|---|-----|
| Expressed as a % of the Measured Velocity                                 | 1.3 |
| Expanded uncertainty at a 95% Confidence Interval                         | 2.5 |

| Measurement Uncertainty Volumetric Flow Rate      | m <sup>3</sup> /hr |
|---|--------------------|
| Combined uncertainty                              | 520                |
| Expanded uncertainty at a 95% Confidence Interval | 1019               |

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

| Expanded Measurement Uncertainty of Volumetric Flow Rate at a 95% Confidence Interval | %   |
|---|-----|
| Expressed as a % of the Measured Volumetric Flow Rate                                 | 2.6 |
| Expanded uncertainty at a 95% Confidence Interval                                     | 5.2 |

Reference – SOCOTEC UK Technical Procedure AE150 Estimation of Uncertainty of Measurement



## END OF REPORT

*Thank you for choosing SOCOTEC UK for your environmental monitoring needs. We hope our services have met your requirements and that you are fully satisfied with your experience of working with us, we really do value your custom and would welcome your feedback. We would appreciate it if you could take a moment to complete a short online questionnaire so that we can improve our operations and address any areas that have not met with your expectations, by clicking on the following*

[https://www.surveymonkey.co.uk/r/CAE\\_customer\\_feedback\\_weblink](https://www.surveymonkey.co.uk/r/CAE_customer_feedback_weblink)