



Element Materials Technology, Unit 4A Adwick Park, Manvers, Rotherham, S63 5AB
Your Element Contact: Derek Myers (07870 177 819)
E: derek.myers@element.com

Stack Emissions Testing Report Commissioned by
Dunlop Oil & Marine Ltd

Installation Name & Address
Dunlop Oil & Marine Ltd
Moody Lane
Pyewipe
Grimsby
DN31 2SY

PPC Permit: EP/200200004/V1

Stack Reference
Donaldson Extract Unit

Dates of the Monitoring Campaign
9th October 2019

Job Reference Number
ERO-2406

| |
|--|
| Report Written by |
| Gary Thackray Technical Manager MCERTS Level 2 MM 02 078 TE1 TE2 TE3 TE4 |

| |
|---|
| Report Approved by |
| Scott Pilkington Deputy Regional Manager MCERTS Level 2 MM 04 501 TE1 TE2 TE3 TE4 |

| |
|--------------------|
| Report Date |
| 30th October 2019 |

| |
|----------------|
| Version |
| Version 1 |

| |
|-------------------------------------|
| Signature of Report Approver |
| |



CONTENTS

TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

| | |
|---------------------------------|---|
| Monitoring Objectives | 3 |
| Monitoring Results | 4 |
| Monitoring Dates & Times | 5 |
| Process Details | 6 |
| Monitoring & Analytical Methods | 7 |
| Summary of Sampling Deviations | 7 |
| Sampling Location | 8 |
| Plant Photos / Sample Points | 9 |

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

Opinions and interpretations expressed herein are outside the scope of Element's ISO 17025 accreditation.

This test report shall not be reproduced, except in full, without the written approval of Element.



Executive Summary

(Page 1 of 7)

MONITORING OBJECTIVES

Dunlop Oil & Marine Ltd, Grimsby
Donaldson Extract Unit
9th October 2019

Overall Aim of the Monitoring Campaign

Element were commissioned by Dunlop Oil & Marine Ltd to carry out stack emissions testing on the Donaldson Extract Unit at Grimsby.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

Special Requirements

There were no special requirements.

Target Parameters

Total Particulate Matter

Executive Summary

(Page 2 of 7)

MONITORING RESULTS

Dunlop Oil & Marine Ltd, Grimsby

Donaldson Extract Unit

9th October 2019

where MU = Measurement Uncertainty associated with the Result

| Parameter | Concentration | | | | Mass Emission | | | |
|---|--------------------|--------|--------|-------|---------------|--------|--------|-------|
| | Units | Result | MU +/- | Limit | Units | Result | MU +/- | Limit |
| Total Particulate Matter ¹ | mg/m ³ | 0.80 | 0.79 | 50 | g/hr | 13.7 | 13.9 | - |
| Water Vapour | % v/v | 0.91 | 0.05 | | | | | |
| Stack Gas Temperature | °C | 23.2 | | | | | | |
| Stack Gas Velocity | m/s | 10.9 | 2.3 | | | | | |
| Volumetric Flow Rate (ACTUAL) | m ³ /hr | 18855 | 4136 | | | | | |
| Volumetric Flow Rate (REF) ¹ | m ³ /hr | 17182 | 3769 | | | | | |

NOTE: VOLUMETRIC FLOW RATE & VELOCITY DATA TAKEN FROM AN AVERAGE OF ALL OF THE ISOKINETIC RUNS.

¹ Reference Conditions (REF) are: 273K, 101.3kPa, without correction for water vapour content.



Executive Summary

(Page 3 of 7)

MONITORING DATE(S) & TIMES

Dunlop Oil & Marine Ltd, Grimsby
Donaldson Extract Unit
9th October 2019

| Parameter | Units | Concentration | Units | Mass Emission | Sampling Date(s) | Sampling Times | Duration mins | |
|--------------------------|-------|-------------------|-------|---------------|------------------|----------------|---------------|----|
| Total Particulate Matter | R1 | mg/m ³ | 0.80 | g/hr | 13.7 | 09/10/2019 | 13:40 - 14:40 | 60 |
| Velocity Traverse | R1 | | | | | 09/10/2019 | 13:40 - 13:45 | |

All results are expressed at the respective reference conditions.



Executive Summary

(Page 4 of 7)

PROCESS DETAILS

Dunlop Oil & Marine Ltd, Grimsby
Donaldson Extract Unit
9th October 2019

Standard Operating Conditions

| Parameter | Value |
|--------------------------------------|------------------|
| Process Status | Normal Operation |
| Capacity (of 100%) and Tonnes / Hour | 100 % Capacity |
| Continuous or Batch Process | Continuous |
| Feedstock (if applicable) | N/A |
| Abatement System | Bag Filter |
| Abatement System Running Status | On |
| Fuel | N/A |
| Plume Appearance | No Plume Visible |



Executive Summary

(Page 5 of 7)

MONITORING & ANALYTICAL METHODS

Dunlop Oil & Marine Ltd, Grimsby
Donaldson Extract Unit
9th October 2019

| Parameter | Monitoring | | | | Analysis | | | | MCERTS Testing | LOD (Average) |
|---------------------------|------------------|---------------------|-------------------|-------------|-----------------------------|----------------------|--------------------|--------------|----------------|------------------------|
| | Standard | Technical Procedure | ISO 17025 Testing | Testing Lab | Analytical Procedure | Analytical Technique | ISO 17025 Analysis | Analysis Lab | | |
| Total Particulate Matter | EN 13284-1 | CAT-TP-01 | Yes | EET | CAT-TP-03 | Gravimetric | Yes | EET | Yes | 0.18 mg/m ³ |
| Water Vapour | EN 14790 | CAT-TP-05 | Yes | EET | CAT-TP-05 | Gravimetric | Yes | EET | Yes | 0.1 % v/v |
| Velocity & Vol. Flow Rate | EN 16911-1 (MID) | CAT-TP-41 | Yes | EET | Pitot Tube and Thermocouple | | | | Yes | 1.8 m/s |

ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

| | |
|-------------------------|--------------------------------------|
| Element Stockport (EET) | ISO 17025 Accreditation Number: 4279 |
|-------------------------|--------------------------------------|

SUMMARY OF SAMPLING DEVIATIONS

| Parameter | Run | Deviation |
|--------------------------|----------|--|
| Total Particulate Matter | All Runs | End of pipe sampling was necessary as there were no sampling ports installed on the stack. |

SUITABILITY OF SAMPLING LOCATION

Duct Characteristics

| Parameter | Units | Value |
|---------------------|----------------|-------------|
| Type | - | Rectangular |
| Depth | m | 0.80 |
| Width | m | 0.60 |
| Area | m ² | 0.48 |
| Port Depth | cm | 0 |
| Orientation of Duct | - | Vertical |
| Number of Ports | - | Grid |
| Sample Port Size | - | Hole |

Location of Sampling Platform

| General Platform Information | Value |
|--------------------------------|---------|
| Permanent / Temporary Platform | MEWP |
| Inside / Outside | Outside |

Platform Details

| EA Technical Guidance Note M1 / EN 15259 Platform Requirements | Value |
|---|-------|
| Sufficient working area to manipulate probe and operate the measuring instruments | Yes |
| Platform has 2 levels of handrails (approx. 0.5m & 1.0m high) | N/A |
| Platform has vertical base boards (approx. 0.25m high) | N/A |
| Platform has chains / self closing gates at top of ladders | N/A |
| There are no obstructions present which hamper insertion of sampling equipment | Yes |
| Safe Access Available | Yes |
| Easy Access Available | Yes |

Sampling Location / Platform Improvement Recommendations

All platforms should be designed in accordance with the requirements in the Environment Agency's Technical Guidance Note M1 and EN 15259.

EN 15259 Homogeneity Test Requirements

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.

Sampling Plane Validation Criteria (from EN 15259)

| Criteria in EN 15259 | Units | Traverse 1 | Required | Compliant |
|------------------------------|-------|------------|----------|-----------|
| Lowest Differential Pressure | Pa | 98.1 | > 5 Pa | Yes |
| Mean Velocity | m/s | 10.8 | - | - |
| Lowest Gas Velocity | m/s | 10.8 | - | - |
| Highest Gas Velocity | m/s | 10.8 | - | - |
| Ratio of Above | : 1 | 1.0 | < 3 : 1 | Yes |
| Maximum Angle of Swirl | ° | 5.0 | < 15° | Yes |
| No Local Negative Flow | - | Yes | - | Yes |

Executive Summary
(Page 7 of 7)

PLANT PHOTOS

Photo 1



Photo 2




Photo 3



Photo 4



SAMPLE POINTS



where

- = isokinetic point sampled at
- = isokinetic point not sampled at
- = combustion gases sample point
- = non-isokinetic sample point



APPENDICES

APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

STACK EMISSIONS MONITORING PERSONNEL

| Position | Name | MCERTS Accreditation | MCERTS Number | Technical Endorsements |
|-------------|---------------|----------------------|---------------|------------------------|
| Team Leader | Gary Thackray | MCERTS Level 2 | MM 02 078 | TE1 TE2 TE3 TE4 |
| Technician | Greg Clough | MCERTS Level 1 | MM 18 1505 | None |

LIST OF EQUIPMENT

| Extractive Sampling | | Instrumental Analysers | | Miscellaneous Items | |
|--------------------------|----------------|--------------------------------|----------------|----------------------------------|------------------------|
| Equipment Type | Equipment I.D. | Equipment Type | Equipment I.D. | Equipment Type | Equipment I.D. |
| Control Box DGM (1) | CAT 7.59 | Horiba PG-250 | - | Digital Manometer (1) | CAT 3.154 |
| Control Box DGM (2) | - | Horiba PG-250 SRM | - | Digital Manometer (2) | CAT 3.156 |
| Box Thermocouples (1) | CAT 3.157 | Servomex 5200 MP | - | Digital Temperature Meter | CAT 3.154 |
| Box Thermocouples (2) | - | Eco Physics CLD 822Mh | - | Stopwatch | CAT 14.53 |
| Umbilical (1) | CAT 3.157 | ABB AO2020-URAS26 | - | Barometer | CAT 13.42 |
| Umbilical (2) | - | Testo 350 XL | - | Stack Thermocouple (1) | - |
| Oven Box (1) | CAT 12.56 | JCT JCC P1 Cooler | - | Stack Thermocouple (2) | - |
| Oven Box (2) | - | Gasmex DX4000 | - | Stack Thermocouple (3) | CAT 4.875 |
| Heated Probe (1) | CAT 5.132 | Gasmex Sampling System | - | 1m Heated Line (1) | - |
| Heated Probe (2) | - | Bernath 3006 FID | - | 1m Heated Line (2) | - |
| Heated Probe (3) | - | M&C PSS | - | 1m Heated Line (3) | - |
| S-Pitot (1) | CAT 21p.159 | Mass Flow Controller (1) | - | 5m Heated Line (1) | - |
| S-Pitot (2) | CAT 21s.58 | Mass Flow Controller (2) | - | 15m Heated Line (1) | - |
| L-Pitot | - | Mass View (1) | - | 20m Heated Line (1) | - |
| Site Balance | CAT 17.35 | Mass View (2) | - | 20m Heated Line (2) | - |
| 500g / 1Kg Check Weights | CAT 17.35 | Hioki 5031 (mA) | - | Dual Channel Heater Controller | - |
| Last Impinger Arm | CAT 4.888 | Hioki 5043 (V) | - | Single Channel Heater Controller | - |
| Callipers | CAT 23.34 | Bioaerosols Temperature Logger | - | Laboratory Balance | CAT 1.18, 1.18a, 1.18b |
| Tubes Kit Thermocouple | - | Electronic Refrigerator | - | Tape Measure | CAT 16.01 |

METHODS & TECHNICAL PROCEDURES USED

| Parameter | Standard | Technical Procedure |
|---------------------------|------------------|---------------------|
| Total Particulate Matter | EN 13284-1 | CAT-TP-01 |
| Water Vapour | EN 14790 | CAT-TP-05 |
| Velocity & Vol. Flow Rate | EN 16911-1 (MID) | CAT-TP-41 |

PRELIMINARY STACK SURVEY: CALCULATIONS

General Stack Details

| Stack Details (from Traverse) | Units | Value |
|--|--------------------|-------|
| Stack Diameter / Depth, D | m | 0.80 |
| Stack Width, W | m | 0.60 |
| Stack Area, A | m ² | 0.48 |
| Average Stack Gas Temperature, T _a | °C | 23.0 |
| Average Stack Gas Pressure | mmH ₂ O | 10.0 |
| Average Stack Static Pressure, P _{static} | kPa | 0.080 |
| Average Barometric Pressure, P _b | kPa | 100.1 |
| Average Pitot Tube Calibration Coefficient, C _p | - | 0.84 |

Stack Gas Composition & Molecular Weights

| Component | Conc ppm | Conc Dry % v/v | Conc Wet % v/v | Volume Fraction r | Molar Mass M | Density kg/m ³ p | Conc kg/m ³ p _i |
|-----------------------------|----------|----------------|----------------|-------------------|--------------|-----------------------------|---------------------------------------|
| CO ₂ (Estimated) | - | 0.06 | 0.06 | 0.0006 | 44.01 | 1.9635 | 0.00118 |
| O ₂ (Estimated) | - | 20.80 | 20.61 | 0.2080 | 32.00 | 1.4277 | 0.29696 |
| N ₂ | - | 79.14 | 78.42 | 0.7914 | 28.01 | 1.2498 | 0.98913 |
| Moisture (H ₂ O) | - | - | 0.91 | 0.0091 | 18.02 | 0.8037 | 0.00735 |

Where: $p = M / 22.41$
 $p_i = r \times p$

Calculation of Stack Gas Densities

| Determinand | Units | Result |
|--|-------------------|--------|
| Dry Density (STP), P _{STD} | kg/m ³ | 1.287 |
| Wet Density (STP), P _{STW} | kg/m ³ | 1.283 |
| Dry Density (Actual), P _{Actual} | kg/m ³ | 1.174 |
| Average Wet Density (Actual), P _{ActualW} | kg/m ³ | 1.170 |

Where: P_{STD} = sum of component concentrations, kg/m³ (not including water vapour)
P_{STW} = sum of all wet concentrations / 100 x density, kg/m³ (including water vapour)
 $P_{Actual} = P_{STD} \times (T_{STP} / (P_{STP})) \times ((P_{static} + P_b) / T_a)$
 $P_{ActualW}$ (at each sampling point) = P_{STW} x (T_s / P_s) x (P_a / T_a)

Calculation of Stack Gas Volumetric Flowrate, Q

| Duct gas flow conditions | Units | Actual | REF ¹ |
|--------------------------|-------|--------|------------------|
| Temperature | °C | 23.0 | 0.0 |
| Total Pressure | kPa | 100.2 | 101.3 |
| Moisture | % | 0.91 | 0.91 |

| Gas Volumetric Flowrate (from Traverse) | Units | Result |
|--|--------------------|--------|
| Gas Volumetric Flowrate (Actual) | m ³ /hr | 18688 |
| Gas Volumetric Flowrate (STP, Wet) | m ³ /hr | 17046 |
| Gas Volumetric Flowrate (STP, Dry) | m ³ /hr | 16890 |
| Gas Volumetric Flowrate REF ¹ | m ³ /hr | 17046 |



APPENDIX 2



PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)

(1 of 1)

| Parameter | Units | Value |
|---------------------------------|--|---------------|
| Date of Survey | - | 09/10/2019 |
| Time of Survey | - | 13:40 - 13:45 |
| Atmospheric Pressure | kPa | 100.1 |
| Average Stack Static Pressure | Pa | 80 |
| Result of Pitot Stagnation Test | - | Pass |
| Are Water Droplets Present? | - | No |
| Device Used | S-Type Pitot with Liquid Incline Manometer | |

| Parameter | Units | Value |
|----------------------------|-------|----------|
| Initial Pitot Leak Check | - | Pass |
| Final Pitot Leak Check | - | Pass |
| Orientation of Duct | - | Vertical |
| Pitot Tube, C _p | - | 0.84 |
| Number of Lines Available | - | 1 |
| Number of Lines Used | - | 1 |

Sampling Line A

| Traverse Point | Depth m | ΔP mmH ₂ O | Temp °C | Wet Density kg/m ³ | Velocity m/s | Swirl ° |
|---------------------------|---------|-----------------------|-------------|-------------------------------|--------------|---------|
| <i>STATIC (Units: Pa)</i> | | 80.0 | | | | |
| Mean | | 10.0 | 23.0 | 1.170 | 10.81 | |
| 1 | 0.40 | 10.0 | 23.0 | 1.170 | 10.81 | 5.0 |

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY

(1 of 1)

| Performance characteristics (Uncertainty Components) | Uncertainty | Value | Units |
|--|--------------------|---------|--------------------|
| Standard Uncertainty on the coefficient of the Pitot Tube | $u(k)$ | 0.005 | - |
| Standard Uncertainty associated with the mean local dynamic pressures | $u(\Delta p_i)$ | 2.186 | Pa |
| - Resolution | $u(res)$ | 0.52154 | |
| - Calibration | $u(cal)$ | 1.001 | |
| - Drift | $u(drift)$ | 1.096 | |
| - Lack of Fit | $u(fit)$ | 1.159 | |
| - Overall corrections to dynamic measurements | $u(C_f)$ | 3.778 | |
| Standard uncertainty associated with the molar mass of the gas | $u(M)$ | 0.00003 | - |
| - $\varphi_{O_2,w}$ | - | 20.610 | |
| - $\varphi_{CO_2,w}$ | - | 0.059 | |
| - Oxygen, dry | $u(\phi_{O_2,d})$ | 0.637 | |
| - Carbon Dioxide, dry | $u(\phi_{CO_2,d})$ | 0.002 | |
| - Water Vapour | $u(\phi_{H_2O})$ | 0.047 | |
| - Oxygen, wet | $u(\phi_{O_2,w})$ | 0.631 | |
| - Carbon Dioxide, wet | $u(\phi_{CO_2,w})$ | 0.002 | |
| Standard uncertainty associated with the stack temperature | $u(T_c)$ | 1.510 | K |
| Standard uncertainty associated with the absolute pressure in the duct | $u(p_c)$ | 175.706 | Pa |
| - Atmospheric Pressure | $u(p_{atm})$ | 175.692 | |
| - Static Pressure | $u(p_{stat})$ | 2.186 | |
| Standard uncertainty associated with the density in the duct | $u(\rho)$ | 0.00631 | - |
| Standard uncertainty associated with the local velocities | $u(v_i)$ | 1.184 | Pa |
| Standard uncertainty associated with the mean velocity | $u(\bar{v})$ | 1.184 | m/s |
| Standard uncertainty associated with the mean velocity (95% Confidence) | $U_c(v)$ | 2.321 | m/s |
| Standard uncertainty associated with the mean velocity (95% Confidence), relative | $U_{c,rel}(v)$ | 21.46 | % |
| Standard uncertainty associated with the volume flow rate (95% Confidence) | $U_c(qV,w)$ | 4099.6 | m ³ /hr |
| - $u^2(a)/a^2$ | - | 0.00053 | |
| - $u^2(qV,w)/q^2V,w$ | - | 0.01253 | |
| - $u^2(qV,w)$ | - | 4374965 | |
| - $u(qV,w)$ | - | 2091.6 | |
| Standard uncertainty associated with the volume flow rate (95% Confidence), relative | $U_{c,rel}(qV,w)$ | 21.94 | % |

TOTAL PARTICULATE MATTER: RESULTS SUMMARY

Dunlop Oil & Marine Ltd, Grimsby
Donaldson Extract Unit

Sample Runs

| Parameter | Units | Run 1 | Mean |
|---------------|--------------------|-------|------|
| Concentration | mg/m ³ | 0.80 | 0.80 |
| Uncertainty | ±mg/m ³ | 0.79 | 0.79 |
| Mass Emission | g/hr | 13.7 | 13.7 |
| Uncertainty | ±g/hr | 13.9 | 13.9 |

| Parameter | Units | Run 1 | Mean |
|--------------|--------|-------|------|
| Water Vapour | % v/v | 0.91 | 0.91 |
| Uncertainty | ±% v/v | 0.05 | 0.05 |

Blank Runs

| Parameter | Units | Blank 1 | Maximum |
|---------------|-------------------|---------|---------|
| Concentration | mg/m ³ | 0.35 | 0.35 |

General Sampling Information

| Parameter | Value |
|--------------------------------|------------------|
| Standard | EN 13284-1 |
| Technical Procedure | CAT-TP-01 |
| Probe Material | Titanium |
| Filter Housing Material | Titanium |
| Positioning of Filter | In Stack |
| Filter Size and Material | 47mm Glass Fibre |
| Number of Sampling Lines Used | 1 / 1 |
| Number of Sampling Points Used | 1 / 1 |
| Sample Point I.D.'s | A1 |

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

TOTAL PARTICULATE MATTER: ISOKINETIC SAMPLING CALCULATIONS

| Test | Units | Run 1 | |
|--|---------------------|--------|--|
| Absolute pressure of stack gas, P_s | | | |
| Barometric pressure, P _b | mmHg | 750.8 | |
| Stack static pressure, P _{static} | mmH ₂ O | 8.2 | |
| $P_s = (P_b + (P_{static} / 13.6))$ | mmHg | 751.4 | |
| Volume of water vapour collected, V_{wstd} | | | |
| Total mass collected in impingers (liquid trap) | g | 3.0 | |
| Total mass collected in impingers (silica trap) | g | 4.1 | |
| Total mass of liquid collected, V _{lc} | g | 7.1 | |
| $V_{wstd} = (0.001246)(V_{lc})$ | m ³ | 0.0088 | |
| Volume of gas metered dry, V_{mstd} | | | |
| Volume of gas sample through gas meter, V _m | m ³ | 1.0650 | |
| Gas meter correction factor, Y _d | - | 0.9640 | |
| Average dry gas meter temperature, T _m | °C | 16.9 | |
| Average pressure drop across orifice, ΔH | mmH ₂ O | 32.7 | |
| $V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$ | m ³ | 0.9580 | |
| Moisture content, B_{w0} & R_{wv} | | | |
| $B_{w0} = V_{wstd} / (V_{mstd} + V_{wstd})$ | m ³ | 0.0091 | |
| B _{w0} as a percentage | % v/v | 0.91 | |
| Reported Water Vapour, checked with Tables in EN 14790, R _{wv} | % v/v | 0.91 | |
| Volume of gas metered wet, V_{mstw} | | | |
| $V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$ | m ³ | 0.9669 | |
| Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂} | | | |
| IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction) | - | No | |
| % wet oxygen measured in gas stream, ACT%O _{2w} | % v/v | N/A | |
| % dry oxygen measured in gas stream, ACT%O _{2d} | % v/v | N/A | |
| % oxygen reference condition, REF%O ₂ | % v/v | N/A | |
| O ₂ Reference Factor wet ($O_{2REFw} = (21 - REF\%O_2) / (21 - ACT\%O_{2w})$) | - | N/A | |
| O ₂ Reference Factor dry ($O_{2REFd} = (21 - REF\%O_2) / (21 - ACT\%O_{2d})$) | - | N/A | |
| $V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$ | m ³ | N/A | |
| $V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$ | m ³ | N/A | |
| Molecular weight of dry gas stream, M_d | | | |
| CO ₂ (Estimated) | % v/v | 0.06 | |
| O ₂ (Estimated) | % v/v | 20.80 | |
| Total | % v/v | 20.86 | |
| N ₂ | % v/v | 79.14 | |
| $M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$ | g/gmol | 28.84 | |
| Molecular weight of stack gas (wet), M_s | | | |
| $M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$ | g/gmol | 28.74 | |
| Velocity of stack gas, V_s | | | |
| Pitot tube velocity constant, K _p | - | 34.97 | |
| Velocity pressure coefficient, C _p | - | 0.84 | |
| Average of velocity heads, ΔP _{avg} | mmH ₂ O | 10.13 | |
| Average square root of velocity heads, √ΔP | √mmH ₂ O | 3.18 | |
| Average stack gas temperature, T _s | °C | 23.2 | |
| $V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (\sqrt{M_s}(P_s))$ | m/s | 10.91 | |
| Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂}) | | | |
| Area of stack, A _s | m ² | 0.48 | |
| $Q_a = (60)(A_s)(V_s)$ | m ³ /min | 314.2 | |
| Conversion factor (K/mm.Hg), C _f | - | 0.3592 | |
| $Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$ | m ³ /min | 286.4 | |
| $Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$ | m ³ /min | 283.7 | |
| $Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$ | m ³ /min | N/A | |
| $Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$ | m ³ /min | N/A | |
| Percent isokinetic, %I | | | |
| Nozzle diameter, D _n | mm | 5.89 | |
| Nozzle area, A _n | mm ² | 27.25 | |
| Total sampling time, q | min | 60 | |
| $\%I = (4.6398E^9)(T_s+273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$ | % | 99.1 | |

TOTAL PARTICULATE MATTER: SAMPLING DETAILS

Sample Runs

| Parameter | Units | Run 1 |
|---------------------------|-------------------|---------------|
| Sampling Times | - | 13:40 - 14:40 |
| Sampling Dates | - | 09/10/2019 |
| Sampling Device | - | ISO |
| Volume Sampled (REF) | m ³ | 0.9669 |
| Filter I.D. Number | - | 47-64962 |
| Start Filter Mass | g | 0.14604 |
| End Filter Mass | g | 0.14620 |
| Total Mass on Filter | g | 0.00016 |
| Probe Rinse I.D. Number | - | PR-47-64962 |
| Start Probe Rinse Mass | g | 2.58539 |
| End Probe Rinse Mass | g | 2.58600 |
| Total Mass in Probe Rinse | g | 0.00061 |
| Total Mass Collected | mg | 0.77 |
| Calculated Concentration | mg/m ³ | 0.80 |
| Balance Uncertainty / LOD | mg/m ³ | 0.18 |

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

| Parameter | Units | Blank 1 |
|------------------------------|-------------------|-------------|
| Blank Dates | - | 09/10/2019 |
| Average Volume Sampled (REF) | m ³ | 0.9669 |
| Filter I.D. Number | - | 47-64961 |
| Start Filter Mass | g | 0.14511 |
| End Filter Mass | g | 0.14523 |
| Total Mass on Filter | g | 0.00012 |
| Probe Rinse I.D. Number | - | PR-47-64961 |
| Start Probe Rinse Mass | g | 2.64575 |
| End Probe Rinse Mass | g | 2.64597 |
| Total Mass in Probe Rinse | g | 0.00022 |
| Total Mass Collected | mg | 0.34 |
| Calculated Concentration | mg/m ³ | 0.35 |
| Balance Uncertainty / LOD | mg/m ³ | 0.18 |

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

| Leak Test Results | Units | Run 1 |
|--------------------------|--------------|--------------|
| Mean Sampling Rate | l/min | 17.1 |
| Pre-Sampling Leak Rate | l/min | 0.20 |
| Post-Sampling Leak Rate | l/min | 0.20 |
| Allowable Leak Rate | l/min | 0.40 |
| Leak Test Acceptable | - | Yes |

| Water Droplets | Units | Run 1 |
|----------------------------|--------------|--------------|
| Are Water Droplets Present | - | No |

| MU (Concurrent Water Vapour) | Units | Run 1 |
|-------------------------------------|--------------|--------------|
| Measurement Uncertainty (MU) | % | 5.6 |
| Allowable MU | % | 20.0 |
| MU Acceptable | % | Yes |

| Silica Gel (Concurrent Water Vapour) | Units | Run 1 |
|---|--------------|--------------|
| Less than 50% Faded | % | Yes |

| Isokinetic Criterion Compliance | Units | Run 1 |
|--|--------------|--------------|
| Isokinetic Variation | % | 99.1 |
| Allowable Isokinetic Range | % | 95 - 115 |
| Isokineticity Acceptable | - | Yes |

| Weighing Uncertainty Criteria | Units | Run 1 |
|--------------------------------------|---------------------|--------------|
| Overall Weighing Uncertainty | ± mg | 0.32 |
| Overall Weighing Uncertainty | ± mg/m ³ | 0.33 |
| ELV [Daily ELV for IED] | mg/m ³ | 50.00 |
| Allowable Weighing Uncertainty | mg/m ³ | 2.50 |
| Weighing Uncertainty Acceptable | - | Yes |

| Filter Temperatures | Units | Run 1 |
|-------------------------------|--------------|--------------|
| Pre-Conditioning Temperature | °C | 180 |
| Post-Conditioning Temperature | °C | 160 |
| Maximum Filter Temperature | °C | 24 |

| Test Conditions | Units | Run 1 |
|-------------------------------|--------------|--------------|
| Ambient Temperature Recorded? | - | Yes |



TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 2 OF 2)

Blank Runs

| Leak Test Results | Units | Blank 1 |
|------------------------|-------|---------|
| Expected Sampling Rate | l/min | 20.0 |
| Pre-Sampling Leak Rate | l/min | 0.20 |
| Allowable Leak Rate | l/min | 0.40 |
| Leak Test Acceptable | - | Yes |

| Validity of Blank vs ELV | Units | Blank 1 |
|--------------------------|-------------------|---------|
| Allowable Blank | mg/m ³ | 5.0 |
| Blank Acceptable | - | Yes |

| Acetone / Water Rinse Blank | Units | Blank |
|-----------------------------|-------|-------|
| Acetone / Water Rinse Value | mg/l | 2.7 |
| Allowable Blank | mg/l | 10 |
| Blank Acceptable | - | Yes |

Method Deviations

| Nature of Deviation | Run Number |
|---|------------|
| (x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run) | 1 |
| End of pipe sampling was necessary as there were no sampling ports installed on the stack. | x |

TOTAL PARTICULATE MATTER: MEASUREMENT UNCERTAINTY CALCULATIONS

| Measured Quantities | Value | | Standard uncertainty | | |
|-------------------------|----------------|--------|----------------------|----------------|--------|
| | Symbol | Run 1 | Symbol | Units | Run 1 |
| Sampled Volume (Actual) | V _m | 1.0650 | uV _m | m ³ | 0.0213 |
| Sampled Gas Temperature | T _m | 289.9 | uT _m | K | 2.0 |
| Sampled Gas Pressure | p _m | 100.2 | up _m | kPa | 0.5 |
| Sampled Gas Humidity | H _m | 0.0 | uH _m | % v/v | 1.0 |
| Leak | L | 1.17 | uL | % | - |
| Mass of Particulate | m | 0.77 | um | mg | 0.17 |
| Uncollected Mass | UCM | 0.34 | uUCM | mg | - |

| Measured Quantities | Uncertainty as a Percentage | | Requirement of Standard |
|-------------------------|-----------------------------|-------|-------------------------|
| | Units | Run 1 | |
| Sampled Volume (Actual) | % | 2.00 | ≤2% |
| Sampled Gas Temperature | % | 0.69 | ≤1% |
| Sampled Gas Pressure | % | 0.50 | ≤1% |
| Sampled Gas Humidity | % | 1.00 | ≤1% |
| Leak | % | 1.17 | ≤2% |
| Mass of Particulate | % | 0.35 | <5% of ELV |
| Uncollected Mass | % | - | - |

| Measured Quantities | Uncertainty in Measurement Units | | | Sensitivity Coefficient | |
|----------------------|----------------------------------|-------------------|--------|-------------------------|--|
| | Symbol | Units | Run 1 | Run 1 | |
| Sampled Volume (STP) | V _m | m ³ | 0.9580 | 0.83 | |
| Leak | L | mg/m ³ | 0.005 | 1.00 | |
| Mass of Particulate | L _r | mg | 0.770 | 1.03 | |
| Uncollected Mass | UCM | mg | 0.20 | 1.03 | |

| Measured Quantities | Uncertainty in Result | |
|----------------------|-----------------------|--------|
| | Units | Run 1 |
| Sampled Volume (STP) | mg/m ³ | 0.021 |
| Leak | mg/m ³ | 0.0054 |
| Mass of Particulate | mg/m ³ | 0.1758 |
| Uncollected Mass | mg/m ³ | 0.2030 |

| Measured Quantities | Oxygen Correction Part of MU Budget | |
|---|-------------------------------------|-------|
| | Units | Run 1 |
| O ₂ Correction Factor | - | N/A |
| Stack Gas O ₂ Content | % v/v | N/A |
| MU for O ₂ Correction | - | N/A |
| Overall MU For O ₂ Measurement | % | N/A |

| Parameter | Units | Run 1 |
|---|-------------------|-------|
| Combined uncertainty | mg/m ³ | 0.27 |
| Expanded uncertainty (95% confidence), without Oxygen Correction | mg/m ³ | 0.53 |
| Expanded uncertainty (95% confidence), with Oxygen Correction | mg/m ³ | N/A |
| Expanded uncertainty (95% confidence), estimated with Method Deviations | mg/m ³ | 0.79 |
| Reported Uncertainty | mg/m ³ | 0.79 |
| Expanded uncertainty (95% confidence), without Oxygen Correction | % | 66.3 |
| Expanded uncertainty (95% confidence), with Oxygen Correction | % | N/A |
| Expanded uncertainty (95% confidence), estimated with Method Deviations | % | 99.5 |
| Reported Uncertainty | % | 99.5 |